



الشركة العالمية لخدمات التفتيش المحدودة UNIVERSAL INSPECTION CO. LTD.

CR No.2055011643

س.ت ٢٠٥٥٠١١٦٤٣

INSTRUMENT & EQUIPMENT CALIBRATION DIVISION

CERTIFICATE OF CALIBRATION

CERTIFICATE NO: UIC/DAM/59168

This certifies that the instrument below has been tested/calibrated using equipment traceable to National/International Standards or verified by ratio type measurements using self calibrating techniques.

Information on the calibration process and the results are produced below and given in the accompanying sheets of this document.

All related traceable documents are on file at **UNIVERSAL INSPECTION CO. LTD.** and may be examined on request

Customer Sudhir Equipment Rental Company
Location Dammam, Kingdom of Saudi Arabia

Description Pressure Relief Valve
Manufacturer HARSHAD
Part No. N/A
Serial No. 2505936
ID. No. SAC-500-371
Location Calibration Lab (Dammam)

Receipt Date : 18-Jun-25
Calibration Date : 18-Jun-25
Calibration Due Date : 17-Dec-25

The instrument was calibrated using the following reference, maintained at UIC Instrument & Equipment Calibration division conforming to ISO 17025 requirements

Reference Standard Equipment Used

Description	Model / Cert. No.	Serial No.	Due Date
High Pressure Pneumatic Pressure Source	AME/24/TC/1212-A7	214E2408011	13-Dec-25
Digital Pressure Calibrator	AME/24/TC/1212-A12	2232411017	13-Dec-25

Calibrated By

Calibration Engineer

UIC-QP-7.8-24 F02, REV 0

Approved By

QA/QC Engineer

The measurement results pertain only to the instrument calibrated.

This certificate and the attached measurement result sheets shall not be reproduced except in full without the prior permission

P.O. Box No. 2072, Jubail - 31951, K.S.A.
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881
Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية
هاتف ٨٨٨٢ ١٣ ٩٦٦ / فاكس ٨٨٨١ ١٣ ٩٦٦
هاتف ٠٥١٥ ١٣ ٣٦٧ ٩٦٦

CERTIFICATE NO: UIC/DAM/59168		Page	2 of 2
Customer	Sudhir Equipment Rental Company		
Address	Dammam, Kingdom of Saudi Arabia		
Description	Pressure Relief Valve		
Manufacturer	HARSHAD	Calibration Date	18-Jun-25
Model	N/A	Calibration Due Date	17-Dec-25
Serial No.	2505936	Temperature Range	23.5°C
ID. No.	SAC-500-371	Relative Humidity	RH 48%
Test Results			
Set Pressure	: 16.00 BAR	Spring Range	: N/A
Back Pressure	: 0.00 BAR	Size Inlet / Outlet	: 3/4" x 1"
CDTP	: 16.00 BAR	Type of Valve	: Metal Seated
Setting Accuracy	: $\pm 3\%$ of Setting	Test Medium	: AIR
Pop Test	: PASSED		
BASIS OF TEST:			
Ref Standard ASME Sec VIII, Div I			
Summary of Test Procedure:			
The Calibration of above Pressure relief valve is performed through the verification of set pressure and seat tightness using a reference standard pressure gauge or test gauge and a hydrostatic / pneumatic test system.			
Traceability:			
The reported tests were undertaken using equipment detailed mentioned in Reference Standard Equipment's for which the company maintains Traceability to the third party.			
Condition of Instrument			
With in the tolerance on receipt(as found)	No		
The instrument was adjusted	Yes		
The instrument was repaired	No		
***** End of the Certificate *****			
			
Calibrated By:	_____	Approved by:	_____
Calibration Engineer		QA/QC Engineer	