



الشركة العالمية لخدمات التفتيش المحدودة
UNIVERSAL INSPECTION CO. LTD.

CR No.2055011643

س.ت ٢٠٥٥٠١١٦٤٣



CERTIFICATE OF INSPECTION

CERTIFICATE NO: UIC/JED/20241104

Customer : SUDHIR EQUIPMENT RENTAL COMPANY.

Location : JEDDAH - KINGDOM OF SAUDI ARABIA.

Description : POWER GENERATOR

Make : STAMFORD

Model : UCDI274K1

Serial No : C17F233245

ID. No. : SG-171-250

This is to certify that the equipment detailed hereby have been Inspected and test against traceable International Standards for VISUAL & FUNCTIONAL INSPECTION only on the date of Inspection. These conform to functionality and have been Inspected and tested in accordance with the equipment conditions and requirements.

Date of Inspection: 05-OCT-2024

Due Date: 04-OCT-2025

Additional Certification

Sticker Number:156851

Inspected By:



Industrial Inspector



Approved By:

QA/QC Engineer

P.O. Box No. 2072, Jubail - 31951, K.S.A.
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881
Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية
هاتف ٩٦٦ ١٣ ٣٤٤ ٨٨٨٢ / فاكس ٩٦٦ ١٣ ٣٤٤ ٨٨٨١
هاتف ٩٦٦ ١٣ ٣٦٧ ٠٥١٥

CERTIFICATE NO: UIC/JED/20241104**Specifications:**

Rated Power	:	250 KVA
Rated Voltage	:	400 Volt
Rated Frequency	:	60Hz
Rated Current	:	360.8 AMP
Rated Speed	:	1800 RPM
Power factor	:	0.8
Phase	:	3

Reference Standards:

NFPA 110

Comments & Recommendations:

The **Power Generator** was found to be of good working condition and reliable for safe operation.

1. Do not exceed the capacity of the Power Generator.
2. Inspect the Power Generator regularly for damage before every use.
3. Check oil level before operation of the Power Generator.
4. Check the condition of Control panel.
5. Check the operating characteristic before start the Power Generator.
6. Unless otherwise specified, all maintenance and service must be carried out the engine Stopped.
7. **Remember – Safety always comes first!**

Inspected By:


Industrial Inspector

**Approved By:**


QA/QC Engineer

No. 24781

Company Name & Address of the Site Location:

Company / Customer Name : _____

Purchase Order No. : _____

Mr./Mrs: Sudhir Rental

Date Of Calibration / Inspection : 05 / 10 / 2024

Mobile/Tel. No.: _____

Calibration / Inspection Validity : _____ 6M / 1V _____

Email ID : _____

Location : Jeddah

[illegible]

Cal. Engr/Insp. Sign: S Abdul Razik Name: S Abdul Razik

(Client Sign) [Signature] Name: SHMPR Contact No: 053326321 Site Location: JED

Witnessed & Approved by