



الشركة العالمية لخدمات التفتيش المحدودة  
**UNIVERSAL INSPECTION CO. LTD.**

CR No. 2055011643

س.ت ٢٠٥٥٠١١٦٤٣



## **CERTIFICATE OF INSPECTION**

**Certificate No: UIC/20186784**

**Customer :** **Brighten Energy Trading EST,**  
**Address :** Dammam, Kingdom of Saudi Arabia  
**Description :** **Generator**  
**Make :** VARDA ENERGIES  
**Capacity :** 160 KVA  
**Serial No :** N/A  
**ID. No. :** SG-196-160

This is to certify that the device detailed hereby has been inspected and found satisfactory against traceable International Standards for its function on the date of inspection. These conform to manufacturer's specification and have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise noted below, conform in all respects to the specifications relevant here to.

**Date of Testing :** 06-Mar-2019

**Due Date:** 05-Mar-2020

**Additional Certification**

**Sticker Number: 22956**

**Inspected By:**



**Industrial Inspector**



**Approved By:**

**QA/QC Engineer**

P.O. Box No. 2072, Jubail - 31951, K.S.A.  
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881  
Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية  
هاتف ٨٨٨٢ ١٣ ٣٤٤ / فاكس ٨٨٨١ ١٣ ٣٤٤  
هاتف ٠٥١٥ ١٣ ٣٦٧

**Certificate No: UIC/20186784****Specification:**

|                    |   |           |   |                       |   |           |
|--------------------|---|-----------|---|-----------------------|---|-----------|
| Rated Power in kVA | : | 160 Kva   | - | Rated Current (Prime) | : | 222.6Amps |
| Rated Power Factor | : | 0.8       | - | Rated Frequency       | : | 60 Hz     |
| Rated Voltage      | : | 400 Volts | - | Year                  | : | 2018      |
| Speed              | : | 1500 Rpm  | - | Mass                  | : | 2800Kg    |
| Phase              | : | 3         |   |                       |   |           |

**Specification:**

|                |   |               |   |                  |   |             |
|----------------|---|---------------|---|------------------|---|-------------|
| Make           | : | Ashok Leyland | - | Model            | : | AL6DTIG4    |
| Engine Part No | : | A2N21400      | - | Engine Serial No | : | JCHM 422961 |

|                                   |   |                         |
|-----------------------------------|---|-------------------------|
| <b><u>Reference Standards</u></b> | : | BS 5000 Part 3 IEC 34-1 |
|                                   | : | Nema MG 1-3L ISO 8528-3 |
|                                   | : | BSEW 60034-1            |

**Inspection and Test:**

|                      |   |              |   |                      |   |              |
|----------------------|---|--------------|---|----------------------|---|--------------|
| Internal Visual Test | : | Satisfactory | - | General Surface Test | : | Satisfactory |
| Compressor Shut-Down | : | Satisfactory |   |                      |   |              |

**Comments & Recommendations:**

The Generator was found to be of good working condition and reliable for safe operation.

1. Do not exceed the capacity of the Generator.
2. Inspect the Generator regularly for damage before every use.
3. Check oil level before operation and moisture at outlet of the Generator..
4. Check the condition of Control panel.
5. **Remember - Safety always comes first!**

**Inspected By:****Industrial Inspector****Approved By:****QA/QC Engineer**