

Engine Test Certificate

Perkins Engine Company Limited
Eastfield, Peterborough PE1 5FQ
Great Britain
May 13, 2017



This engine has been tested to its maximum rating in accordance with Perkins defined requirements and has performed satisfactorily.

The electronics on this engine have been preset and when the engine has been run-in, the gross power output will be within +/-3% of the gross rating listed below, provided the exhaust and induction systems, fuel and lubricating oils are in accordance with Perkins defined requirements.

Engine Type	Perkins Serial Number	Customer
1506A-E88TAG3	LGDF1012N05212C	Y932

Reference	Technical Data
Emission Capability	UNREGULATED Low SFC
Engine Speed	60 HZ @1800RPM
Engine Type	1506A-E88TAG3
Fuel Consumption-Prime Power	199.4g/Kwh
Fuel Consumption-Standby Max	199.9g/kWH
Gross Engine Power-Prime Power	236 Kw
Gross Engine Power-Standby Max	258 kW
Gross Rating	258 Kw
Net Rating	245 kw

This engine was built and tested in accordance with our approved ISO 9001 Quality Procedure and stated Rating, as determined by the ISO 3046 (BS5541) Standard.

Performance certified as satisfactory.

Signed,

For and on behalf of Perkins Engines Company Limited-Large Engines Division.

MUST BE KEPT WITH ENGINE AT ALL TIMES