

Ownership Certificate

To Whom It May Concern

This is to certify that the following equipment mentioned below are the sole owned by Brighten Energy Trading Est.

Equipment	Diesel Soundproof Generator
Brand / Make	ASHOK LEYLAND
Asset ID	SG-226-60
Model Number	VEPL-62.5-CDP
Serial Number	VEPL-2017/18-0113
Engine Serial Number	HYHM 427493
Alternator Serial Number	G17L487996
Rating	62.5 KVA/50 KW

Mansoor Ali
Accounts & Admin. Manager
Brighten Energy Trading Est
Dammam - KSA





Certificate of Insurance

Policy Holder Name
Policy Number
Original Policy Period

Sudhir Equipment Rental Company
5/EP/30425/0/0
05/04/2026 to 04/04/2027

اسم حامل الوثيقة
رقم الوثيقة
فترة الوثيقة الأصلية

Gulf Insurance Group certifies that above client is holding Contractor's Plant & Machinery Insurance Policy for the below mentioned Equipment in accordance with the above mentioned Insurance Policy:

تشهد مجموعة الخليج للتأمين بأن العميل المذكور أعلاه يحمل وثيقة تأمين على معدات والآلات المقاولين للمعدة المذكورة أدناه، وذلك وفقا لشروط وثيقة التأمين المذكورة أعلاه:

Asset ID	:	SG-226-60	:	معرف الأصل
Brand	:	Ashok Leyland	:	العلامة التجارية
Type	:	VEPL-62.5-CDP	:	النوع
Model	:	Diesel Generator	:	الطراز
Manufacturing Year	:	2017	:	سنة الصنع
Equipment Serial Number	:	VEPL-2017/18-0113	:	الرقم التسلسلي للمعدة
Purchase Value	:	37000	:	قيمة الشراء
Insurance Effective Date	:	05/04/2026	:	تاريخ سريان التأمين

This Certificate has been issued upon Insureds request as per all terms and conditions, exclusions, warranties mentioned in the policy.

تم اصدار هذه الشهادة بناء على طلب المؤمن له وذلك حسب الشروط والاستثناءات والاشتراطات المذكورة في الوثيقة

Al Khobar : 01st April 2026

Signature of Insurer's Authorized Representative



PUBLIC

Gulf Insurance Group

A Saudi joint stock company | Paid-up capital 500 Million Saudi Riyals
Licensed by No (TMN/25/20101) | Commercial Registration No.1010271203
3528 King Abdullah Bin Abdulaziz Road, Al Nuzha District
Unit No. 25 | Riyadh 12471 - 6378
Toll free 8001160020 | Website www.gig.sa
Regulated and Supervised by The Saudi Central Bank

مجموعة الخليج للتأمين

شركة مساهمة سعودية | رأس المال 500,000,000 ريال سعودي
مرخص لها برقم ترخيص (ت م ن/25/20101) | سجل تجاري رقم 1010271203
3528 طريق الملك عبدالله بن عبدالعزيز، حي النزهة
رقم الوحدة 25 | الرياض 12471 - 6378
www.gig.sa الرقم المجاني 8001160020 | الموقع الإلكتروني
خاضعة لرقابة وإشراف البنك المركزي السعودي



REPORT OF A THOROUGH EXAMINATION

Issue Date: 05-Apr-2026

Certificate Number: ECI/SA/C-00338/26 Rev. No: 00	Report Number: 129807	Sticker Number: 107850
Date of Thorough Examination: 04-Apr-2026	Date of Expiration: 03-Oct-2026	S.O.#: DMM/04-26/001 Ref.#: N/A

Client: SUDHIR EQUIPMENT RENTAL COMPANY	Address of Premises at Which the Examination Was Made: DAMMAM
---	---

Description and Identification of the Equipment:	Load Test Detail	Safe Working Load(s)	Applied Load(s)
Equipment / Type : INDUSTRIAL EQUIPMENT / GENERATOR Location of the Equipment : DAMMAM YARD Equipment ID No : SG-226-60 Equipment Serial No : VEPL-2017/18-0113 Model : VEPL-62.5-CDP Manufacturer / Date of Manufacture : STAMFORD / 2017 Applied Standard : ISO 8528-13 : 2016	N/A	60 kVA	N/A

Examination after installation / In-Services		Was the Examination carried out Within an interval of					
☐ Initial ☒ Periodic Inspection ☐ Re-Inspection after Major Repair / Modification Or Overhaul		☐ 3 Months ☒ 6 Months ☐ 12 Months ☐ After the exceptional circumstances					
Additional Information about the equipment and Information / Description of the Parts / attachments with the equipment.							
Description of the Load Test : N/A							
Pre Load Test NDT done by : N/A		% of Load Applied : N/A		Post Load Test NDT done by : N/A			
Expiration of Load Test : N/A							
Result				PASS	☒	FAIL	
Is the above a defect which is of immediate danger to persons?				YES		NO	☒
Is the above a defect which is not yet but could become a danger to persons?				YES by :		NO	☒
Particulars of any repair, renewal or alteration required to remedy the defect identified above: N/A							
Is this equipment safe to operate?				YES	☒	NO	

Note: We thus attest that the aforementioned equipment has undergone a thorough Visual Inspection and /or Functional Test conducted by a qualified inspector in accordance with Engineering Corner for Inspection (E.C.I.) procedure / local / international standards.

Liability: The client or this assignee or supervisor in interest agrees to identify and hold harmless **Engineering corner for inspection Co.Ltd.** from and against any all claims, demands, lawsuits or actions for damages including legal fees to persons and/or property tangible, intangible or otherwise which may be against, **Engineering corner for inspection Co.Ltd.** incidental to, arising out of or in connection with the work to be done, services to be performed or material to be furnished hereunder except for those claims caused solely and completely by the negligence of **Engineering corner for inspection Co.Ltd.** its directors, others, employees or sub-contractors.

Inspected by: MOHAMED ABDUL BARICK	Approved & Reviewed By: ALVARO	QR Code:
Signature:		

	Engineering Corner for Inspection Company Limited Inspection Checklist for Electric Generator	Doc. No.	ECIR - LFT - 108
		Rev. No.	03
		Rev. Date	17-FEB-2026
		Page No.	2 of 3

Issue Number : 02 & Issue Date : 03-FEB-2020

Equipment Owner	SUDHIR EQUIPMENT RENTAL COMPANY /	Report No. & Date	129807 04-Apr-2026
Manufacturer / year	STAMFORD / 2017	Location	DAMMAM YARD
Type / Model	INDUSTRIAL EQUIPMENT / GENERATOR / VEPL-62.5-CDP	Equipment ID. No.	SG-226-60
Inspection Date	04-Apr-2026	Equipment Sr. No.	VEPL-2017/18-0113
Inspector Name	MOHAMED ABDUL BARICK	Capacity / SWL	60 kVA
Reference Document / Standard	ISO 8528-13 : 2016	Expiration Date	03-Oct-2026

Item No	ITEM NAME	PASS	FAIL	N/A	Item No	ITEM NAME	PASS	FAIL	N/A
DOCUMENTATION					17	Terminal connections tight and corrosion-free	☒		
1	Manufacturer documents / OEM certificates	☒			18	Grounding and bonding connections secure	☒		
2	Previous inspection report or certificates	☒			19	Control panel clean, labeled, and functional	☒		
3	Installation and commissioning records	☒			20	Circuit breakers and protective devices operational	☒		
4	Electrical test certificates	☒			21	Voltage regulator and AVR functioning correctly	☒		
5	Maintenance and service logs	☒			22	Excitation system (if applicable) operational	☒		
RATINGS AND MARKINGS					FUEL AND ENGINE SYSTEMS				
6	Manufacturer name / Trade mark visible	☒			23	Fuel tank secure, clean, and free from leaks	☒		
7	Model and serial number legible	☒			24	Fuel lines and filters clean and unobstructed	☒		
8	Voltage, current, and frequency ratings marked	☒			25	Oil level and condition within specification	☒		
9	Power rating (kVA/kW) clearly labeled	☒			26	Coolant level and condition adequate	☒		
10	IP rating and environmental compliance marked	☒			27	Air filter clean and unrestricted	☒		
PHYSICAL AND STRUCTURAL COMPONENTS					28	Battery condition and charge level acceptable	☒		
11	Generator enclosure free from damage, corrosion, or leaks	☒			SAFETY AND WARNING DEVICES				
12	Mounting points and base secure and undamaged	☒			29	Emergency stop button accessible and functional	☒		
13	Cooling system (radiator, fan) clean and operational	☒			30	Alarms and warning indicators operational	☒		
14	Exhaust system secure and free from leaks	☒			31	Automatic start/stop system functional	☒		
15	Vibration isolators and mounts intact and secure	☒			32	Load testing performed and recorded	☒		
ELECTRICAL AND SYSTEM					33	Remote monitoring/control system functional (if installed)	☒		
16	Wiring and cables intact, no cuts or abrasions	☒							

Overall Comments

Inspected By : MOHAMED ABDUL BARICK	Customer Representative : ARIF
--	---------------------------------------



**ENGINEERING CORNER FOR
INSPECTION CO. LTD. (ECI)**



ECI. 107850

Capacity : 60 kVA

Equipment No. : SG-226-60

Serial No. : VEPL-2017/18-0113

Inspected Date : 04-Apr-2026

Next Inspection : 03-Oct-2026

Inspector : MOHAMED ABDUL BARICK

P.O.Box 235 Rastanura 31941 Kingdom of Saudi Arabia

Tel.: (013) 667-6999 / 667-6895 Fax #:(013) 667-6894

E-mail Address:eci@eccgroupksa.com