

CERTIFICATE OF THOROUGH EXAMINATION OF DIESEL GENERATOR

Date of thorough examination : 17-12-2025	Date of issue : 18-12-2025	Report No. : ESICO-LFT-R25-7056
---	----------------------------	--

Name & Address of employer	Location	Sticker	Standards
SUDHIR EQUIPMENT RENTALS COMAPNY	RIYADH YARD	8708	BS 5410-3:2023/ ISO 8528

Equipment Identification No	Equipment Description	Safe Working Load(s)	Date of Manufacture	Manufacturer Name
SG-259-250 OR C18PI502726	DIESEL GENERATOR MODEL:PI250C POWER: 182KW ENGINE SPEED:1500RPM POWER FACTOR:0.8 LAGGING FREQUENCY:50HZ VOLTAGE:400-480V PHASE:3 POLE:4 POWER OUT PUT: 228KVA	CURRENT : APROXIMATELY 346 AMPS AT FULL LOAD	2017	PRECISION INDUSTRIES

Is this the first examination after installaton or assembly at a new site or location?	Yes - No ☒	Was the examination carried out within an interval of?	- 6 Months
If the answer to the above question is YES, has the equipment been installed correctly?	Yes - No -	In accordance with an examination scheme?	Yes ☒ No -
		After the occurence of exceptional circumstances?	Yes - No ☒

Identification of any part found to have a defect which is or could become a danger to persons and a description of the defect (if none state NONE) : NONE	
Is the above an existing or imminent danger to persons, Note: This is a reportable defect?	No
Is the above a defect which is not yet could become a danger to persons (if YES state the date by when)	Yes by : N/A
Particulars of any repair, renewal or alteration required to remedy the defect identified above : NONE	
Particulars of any tests carried out as part of the examination (if none state NONE) : VISUAL INSPECTION AND FUNCTIONAL TEST.	
Observation/additional comments relative to this thorough examination : AT THE TIME OF INSPECTION THE EQUIPMENT ABOVE NAME IS SAFE TO OPERATE.	



For confirmation scan QR code
search with report number : **ESICO-LFT-R25-7056**

☒ Safe to operate

Next Inspection : 16-06-2026

Inspected by : Jay Prakash

