

Engine Test Certificate

Perkins Engine Company Limited
Eastfield, Peterborough PE1 5FQ
Great Britain
Dec 15, 2017



This engine has been tested to its maximum rating in accordance with perkins defined requirements and has performed satisfactorily.

the electronics on this engine have been preset and when the engine has been run-in, the gross power output will be within +/-3% of the gross rating listed below, provided the exhaust and induction systems, fuel and lubricating oils are in accordance with perkins defined requirements.

Engine Type	Perkins Serial Number	Customer
2806A-E18TAG2	JGBF5151N04115C	Y932

Reference	Technical Data
Emission Capability	UNREGULATED Low SFC
Engine Speed	60 HZ @1800RPM
Engine Type	2806A-E18TAG2
Fuel Consumption-Prime Power	202 g/Kwh
Fuel Consumption-Standby Max	203 g/kWH
Gross Engine Power-Prime Power	584 Kw
Gross Engine Power-Standby Max	628 kW
Gross Rating	584 Kw
Net Rating	565 kw

This engine was built and tested in accordance with our approved ISO 9001 Quality Procedure and stated Rating, as determined by the ISO 3046 (BS5541) Standard.

performance certified as satisfactory.

signed,

for and on behalf of Perkins Engines Company Limited-Large Engines Division.

MUST BE KEPT WITH ENGINE AT ALL TIMES