



الشركة العالمية لخدمات التفتيش المحدودة

UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت. ٢٠٥٥٠١١٦٤٣



## CERTIFICATE OF INSPECTION

Certificate No: UIC/DAM/20201825

**Customer :** Sudhir Equipment Rental Company

**Address :** Dammam, Kingdom of Saudi Arabia

**Description :** Generator

**Make :** PERKINS

**Model :** 2806A-E18TAG2

**Serial No :** JGBF5151N03689C

**ID.No :** SG-263-650

This is to certify that the device detailed hereby has been inspected and found satisfactory against traceable International Standards for its function on the date of inspection. These conform to manufacturer's specification and have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise noted below, conform in all respects to the specifications relevant here to.

**Date of Testing :** 09-Apr-2022

**Due Date :** 08-Apr-2023

**Additional Certification**

**Sticker Number:** 55169

**Inspected By:**

9  
INSPECTOR  
**Industrial Inspector**



**Approved By:**

21. Tash  
**QA/QC Engineer**

P.O. Box No. 2072, Jubail - 31951, K.S.A.  
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881  
Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية  
هاتف ٨٨٨٢ ١٣ ٣٤٤ / فاكس ٨٨٨١ ١٣ ٣٤٤  
هاتف ٠٥١٥ ٣٦٧ ١٣ ٩٦٦

**Certificate No: UIC/DAM/20201825****Specifications:**

|                      |   |           |   |                  |   |            |
|----------------------|---|-----------|---|------------------|---|------------|
| Rated Power Stand By | : | 650 KVA   | - | Rated Power      | : | 536 KW     |
| Speed                | : | 1800 Rpm  | - | Rated Amps       | : | 932 A      |
| Rated Voltage        | : | 110-415 V | - | Rated Frequency  | : | 60 Hz      |
| Phase                | : | 3         | - | Power Factor     | : | 0.8        |
| Alternate Make       | : | Stamford  | - | Alternate Ser No | : | A17G294756 |

**Engine Specifications:**

|                  |   |                 |   |                |   |          |
|------------------|---|-----------------|---|----------------|---|----------|
| Engine Make      | : | Perkins         | - | Engine Part No | : | JGBF5151 |
| Engine Serial No | : | JGBF5151N03689C |   |                |   |          |

**Inspection and Test:**

|                      |   |              |   |                      |   |              |
|----------------------|---|--------------|---|----------------------|---|--------------|
| Internal Visual Test | : | Satisfactory | - | General Surface Test | : | Satisfactory |
| Compressor Shut-Down | : | Satisfactory |   |                      |   |              |

**Comments & Recommendations:**

The Generator was found to be of good working condition and reliable for safe operation.

1. Do not exceed the capacity of the Generator.
2. Inspect the Generator regularly for damage before every use.
3. Check oil level before operation and moisture at outlet of the Generator.
4. Check the condition of the nozzles regularly.
5. Check the condition of Radiator in equal interval.
6. Unless otherwise specified, all maintenance and service must be carried out the engine Stopped.
7. **Remember - Safety always comes first!**

**Inspected By:****Industrial Inspector****Approved By:**
**QA/QC Engineer**