

Certificate of Visual Examination

Client Name :		
Sudhir Gensets Co.		
Work/ Rig Location:	Certificate Number:	Issued Sticker No.(if Applicable)
Sudhir Gensets Base	ZM-20-Z014- 1860	W.4461
Date of Last Inspection	Date of Inspection:	Date of Next Inspection:
3-Dec-2018	8-Nov-2020	7-Nov-2021
Relevant Standards:	O.E.M / C.O.C / Reverse Engineering Cert. No.	Color Code (If Applicable for the item) (Current applicable Color at the Time of Inspection)
ISO 8528-3:2020 / 60034-22:2009	C17J435362	
Zamil Ref No.	Customer Requisition No.	N/A
ZAM-2299-11-20	SG-EPO-2020-0148	

I.D. NUMBER	QTY	DESCRIPTION	SWL / CAPACITY
SG-270-250	1	Diesel Soundproof Generator Model No : 1506A-E88TAG3 Asset No : SG-270-250 Engine Serial No : LGDF1012N07749C Rating : 250 KVA / 200 KW Manufacture : Perkins NOTE : Visual Inspection & Functional Test Were Carried Out On The Above Mentioned Equipment , At The Time Of Inspection No Any Abnormality Found.	250 KVA / 200 KW


Result: During the Time of Visual Inspection, Result found Satisfactory.

This Certificate by Company Under Its General Conditions of Services. This Issuance of This Certificate Does Not Exonerate the Buyers or Sellers from Exercising All Their Rights Discharging All Their Liabilities Under the Contacts of Sale. Stipulations to Contrary Are Not Binding on The Companies Responsibility Under This Certificate is Limited to Proven Negligence and Will in No Case Be More Than Ten Times the Amount of The Free or Commission. The Above Findings Are Limited to Date Place of Intervention Only. The Company is Neither an Insurer Not a Guarantor Disclaims All Liabilities in Such Capabilities.

Inspected By:
Name : Mohamed Nagiub
Qualifications : LEEA & ASNT NDT Level II Certified

Signature & Stamp:





طريق الملك فهد - حي الضباب - الدمام - س.ت: 2050069798 - ص.ب 419 - الدمام 31411

King Fahad Road - Al-Dhabab Avenue - Dammam - C.R.: 2050069798 - P.O. Box 419 - Dammam 31411 Email: info@zamil.sa