

Engine Test Certificate

Perkins Engine Company Limited
Eastfield,Peterborough PE1 5FQ
Great Britain
Dec 13,2017



This engine has been tested to its maximum rating in accordance with perkins defined requirements and has performed satisfactorilly.

the electronics on this engine have been preset and when the engine has been run-in, the gross power output will be within +/-3% of the gross rating listed below,provided the exhaust and induction systems,fuel and lubricating oils are in accordance with perkins defined requirements.

Engine Type	Perkins Serial Number	Customer
2206A-E13TAG3	TGBF5130N04497C	Y932

Reference	Technical Data
Emission Capability	UNREGULATED Low SFC
Engine Speed	60 HZ @1800RPM
Engine Type	2206A-E13TAG3
Fuel Consumption-Prime Power	204 g/KWH
Fuel Consumption-Standby Max	205 g/KWH
Gross Engine Power-Prime Power	368.4 KW
Gross Engine Power-Standby Max	412.5 KW
Gross Rating	368.4 KW
Net Rating	348.9 KW

this engine was built and tested in accordance with our approved ISO 9001 Quality Procedure and stated Rating,as determined by the ISO 3046 (BS5541)Standard.

perfomance certified as satisfactory.

signed,

for and on behalf of Perkins Engines Company Limited-Large Engines Division.

MUST BE KEPT WITH ENGINE AT ALL TIMES