



CERTIFICATE OF GENERATOR PERFORMANCE TEST REPORT

This report complies with the requirements of the Visual Inspection & Functional Operations

Date of Thorough Examination	Date of Certificate	Certificate number	Sticker Number
24-Sep-2024	24-Sep-2024	UIC/DUB/20221736	144034
Next Examination Due Date	Date of last thorough examination	Reference Standard	Order No
23-Sep-2025	14-Sep-2023	BS EN 60034-22:2009	N/A
Name and Address of Customer		Address of Examination	
SUDHIR RENTALS		(L&T) AL BADA, KSA	
Description and identification of the equipment		Equipment ID	Capacity
GENERATOR Manufacturer: PRECISION INDUSTRIES Model: PI250C, Id no: SG-317-250 Rating power: 228 KVA / 182 KW, Phase: 3, Engine Speed: 1800 Rpm, Rated Power Factor: 0.8 Frequency: 60 Hz, Temperature: 50°C Rated Voltage: 220 V, Manufacture year: AUG-2018.		H18P1503380	-
Is this the first Examination after installation or assembly at a new site or location?	NO	Was the Examination carried out within an interval of 6 months?	NO
Has the equipment been installed correctly?	YES	Was the Examination carried out within an interval of 12 months?	YES
Identification of any part found to have a defect which is or could become a danger to persons and a description of the defect:			
NONE			
Is the above an existing or imminent danger to persons?			
NO			
Is the above a defect which is not yet but could become a danger to persons:			
NONE			
Particulars of any repair, renewal or alteration required to remedy the defect identified above:			
NONE			
Particulars of any tests carried out as part of the examination. And standard applied			
This Generator has been Visually, Functionally Examined, in accordance with BS EN 60034-22:2009.			
IS THIS EQUIPMENT SAFE TO OPERATE?		YES	
Name and Signature of the person issue this certificate.	Name and Signature of the person authenticating this certificate.		
Name:	Name:		
MUHAMMED SUHAIL	ABDUL KHALEEL		
Signature:	Signature:		
At the time of inspection, the equipment was found satisfactory and free from any defects and damage and found safe for use. UNIVERSAL INSPECTION CO. LTD. is not holding any responsible for any damage occurring after the inspection date due to improper use pertaining to operation as per the manufacturer's manual, maintenance, and servicing.			