

Certificate of Visual Examination

Client Name :		
Sudhir Equipment Rental Company		
Work/ Rig Location:	Certificate Number:	Issued Sticker No.(if Applicable)
Dammam	ZAM-040-21- 403	W.7007
Date of Last Inspection	Date of Inspection:	Date of Next Inspection:
N/A	4-May-2021	3-Nov-2021
Relevant Standards:	O.E.M / C.O.C / Reverse Engineering Cert. No.	Color Code (If Applicable for the item) (Current applicable Color at the Time of Inspection)
BS5000 Part3IEC34-1 & ISO-8528	PI250C	
Zamil Ref No.	Customer Requisition No.	N/A
ZAM-0266-05-21	N/A	

I.D. NUMBER	QTY	DESCRIPTION	SWL / CAPACITY
H18PI503360	01	Silent Generator Model : PI250C ID : SG-317-250 Manufacture : PRECISION 2016 Engine S/N : QSB7G5-84466619 KW : 162 Stand By Power : 250 KVA Prime Power : 226 KVA Rating Voltage : 220V Rating Frequency : 60 HZ Weight : 3250 Kg Location : SUDHIR Yard NOTE : Visual Inspection & Functional Test Were Carried Out On The Above Mentioned Equipment , At The Time Of Inspection No Any Abnormality Found.	N/A

Result: During the Time of Visual Inspection, Result found Satisfactory.

This Certificate by Company Under Its General Conditions of Services. This Issuance of This Certificate Does Not Exonerate the Buyers or Sellers from Exercising All Their Rights Discharging All Their Liabilities Under the Contacts of Sale. Stipulations to Contrary Are Not Binding on The Companies Responsibility Under This Certificates Is Limited to Proven Negligence and Will in No Case Be More Than Ten Times the Amount of The Free or Commission. The Above Findings Are Limited to Date Place of Intervention Only. The Company Is Neither an Insurer Not a Guarantor Disclaims All Liabilities in Such Capabilities.

Inspected By:
Name : Mohamed Youssry
Qualifications : LEEA & ASNT NDT Level II Certified

Signature & Stamp:





طريق الملك فهد - حي الضباب - الدمام - س.ت: 2050069798 - ص.ب 419 - الدمام 31411

King Fahad Road - Al-Dhabab Avenue - Dammam - C.R.: 2050069798 - P.O. Box 419 - Dammam 31411 Email: info@zamil.sa