

SA-318-250



Precision Industries
Testing Department

GENERATING-SET

LOAD TEST

Model No: PI 250 C 60 Hz

Type: Close Job No: 9428

Color: White Date: 12/08/2018

Serial Number:								
PI Model No:	PI 250 C	Prime Power:	225	[kVA]	P.F (Load):	1	Voltage:	220

Generating Set Details:

Engine:	Cummins	Model No: QSB7 - G5	Serial No: 84468606
Alternator:	Stamford	Model No: UCI 274 H1	Serial No: N17D176585
Controller:	DSE	Model No: 6120	Serial No: 6729557
C. Breaker:	Metasol 800 A	Model No: ABN 803 C	Serial No: N/A
C.Transformer:	Ziegler 800/5A	Model No: N/A	Serial No: N/A
AVR:	Stamford	Model No: SX 460	Serial No: 111505 - 2206
Cooling System: Water Cool	Enclosure Type: Canopy	Protection Class: IP23	

Load Test Ambient Conditions:

Temperature	38	[°C]	Altitude:	0	[m]	Humidity:	53	%
-------------	----	------	-----------	---	-----	-----------	----	---

Generating Set Rating:

Testing Full Load Current:	472.38	Amps	Nominal Current:	590.5	Amps
Power Correction Factor (De-rating):	0.000	%	Corrected Prime Power:	0.0	[kVA]

LOAD TEST

Load	Run Time	Freq	Speed	VOLTAGE L-L			CURRENT			Power	Coolant Temp	Oil Pressure	Charg-Alt.
				L1	L2	L3	L1	L2	L3				
%	min	Hz	RPM	V	V	V	A	A	A	kW	C	bar	VDC
0 %	5	60	1800	220	220	220	-	-	-	-	70	4.68	14.6
25 %	5	60	1800	220	220	220	118	117	116	45.0	79	4.28	14.6
50 %	5	60	1800	220	220	221	239	238	238	91.0	82	3.96	14.6
75 %	5	60	1800	220	221	221	356	355	356	135.0	83	3.80	14.7
100 %	10	60	1800	220	221	222	474	474	473	181.0	89	3.48	14.8
110 %	10	60	1800	220	221	222	519	519	518	198.0	95	3.42	14.8

LOAD ACCEPTANCE TEST

Suddenly Block Load %	Voltage [V]	Frequency [Hz]	Currnet [A]	Response Time [sec]
50%	220	60.0	239	0
0%	226 - 220	61.7 - 60.0	0	2
50%	215 - 220	58.5 - 60.0	244	2

PROTECTION SYSTEM TEST

Over Frequency Warning / SD	Under Frequency Warning / SD	Over Voltage Warning / SD	Under Voltage Warning / SD	Oil Pressure SD	Coolant Level Warning / SD	Coolant Temp Warning / SD
65 / 67	55 / 57	240 / 260	190 / 180	1.0	OK	103 / 108 C

ACCESSORIES DETAILS

Model:		Serial No.	
Model:		Serial No.	

TESTED
Testing Department

PI Document no. PI-TST-LT-01 Rev. 01