

BUREAU
VERITAS
☐ Interim
☒ Final

INSPECTION REPORT

NO. R107210622.03

BV Job nr: KHO.INI.19.206.SA.

PROJECT: Third Party Inspection for Diesel Soundproof Generator	Ref: KHO.INI.19.206.SA
BV Client: Sudhir Rentals	P/o nr: N/A (client to BV)
Manufacturer: Ashok Leyland	

SUPPLY / SUBJECT OF INSPECTION	SN / TAG Nr	Owner ID No	QTY
VISUAL EXAMINATION AND FUNCTIONAL TEST OF DIESEL SOUNDPROOF GENERATOR	VEPL/2018-19/0020	SG-322-125	1

DOCUMENTS OF REFERENCE : See continuation sheet for additional documents: ☐ Yes ☐ No				
Title	Reference n°	Rev.	Approved by	Date
EQUIPMENT DATA SHEET	-	-	Ashok Leyland	-

INSPECTIONS : <u>Inspection place & Date or Period:</u> Sudhir Rental Warehouse, June 22, 2021 <u>Stage of inspection :</u> ☐ Before manufacturing ☐ During manufacturing ☒ Final ☐ Packing <u>Type of inspection:</u> ☐ Pre-inspection meeting ☐ Document and QC record review ☒ Visual examination, checks ☐ Witnessing tests ☐ Manufacturing progress status ☐ Vendor assessment ☒ Final inspection ☐ Packing (for details see continuation sheet) <u>Stamping :</u> ☒ No ☐ ☐	<u>Results of inspection :</u> ☒ Satisfactory ☐ Unsatisfactory <u>Non Conformities Reports (NCR):</u> o NCR's issued during reported period : N/A o List of outstanding NCR's : N/A <u>Main Conclusions & Remarks:</u> (for details see continuation sheet) Third party visual inspection and functional test of one unit of Generator was carried out and found satisfactory at the time of Inspection. Valid Sticker Number : LTF-S-01-26322 Next visit scheduled: June 21, 2022
--	--





INSPECTION REPORT

NO. R107210622.03

☐ Interim
☒ Final

BV Job nr: KHO.INI.19.206.SA.

Description of the inspections carried out:**1. Introduction:**

The undersigned surveyor to Bureau Veritas acting within the scope of work along with the General condition which Regulate the intervention of the society IVS Department at the Request of Sudhir Rental Co. on the purpose of Third Party Inspection.

2. Scope of Inspection :

Visual Inspection & Functional Test of Diesel Soundproof Generator.

1- General Data	
Equipment Type	Diesel Soundproof Generator
Manufacturer	Ashok Leyland
Model	VEPL-125-CDP
Serial No.	VEPL/2018-19/0020
Owner ID No	SG-322-125
Rating Power	125 KVA/ 100 KW

3- Inspection and Test Results		
Acceptance criteria	Result	Remarks
1. Document review (Original Declaration of Conformity)	Pass	Available
2. Visual inspection of Unit-leaks, wear, damage, loose connection/components, corrosion.	Pass	Found good condition.
3. Check air filter and engine oil level	Pass	Found good condition.

➤ Conclusion:

The Generator was found satisfactory and in good running condition at the time of Inspection.

Surveyor's name: Mahmoud El Nahas

Signature:



Authorized by lifting operations team leader :

Signature:

Issued at Al Khobar office on 22 June 2021