



Precision Industries
Testing Department

GENERATING-SET
LOAD TEST

Model No: PI 250 C 60 Hz
Type: Close Job No: 9522
Color: White Date: 01/11/2018

Serial Number:								
PI Model No:	PI 250 C	Prime Power:	228	[kVA]	P.F (Load):	1	Voltage:	220

Generating Set Details:

Engine:	Cummins	Model No: QSB7 - G5	Serial No: 84495546
Alternator:	Stamford	Model No: UCI 274 H1	Serial No: N18G271009
Controller:	DSE	Model No: 6120	Serial No: 6865747
C. Breaker:	Metasol	Model No: ABN 803C	Serial No: N/A
C.Transformer:	Ziegler 800/5A	Model No: N/A	Serial No: N/A
AVR:	Stamford	Model No: SX 460	Serial No: 112101 - 3553
Cooling System:	Water Cool	Enclosure Type: Canopy	Protection Class: IP23

Load Test Ambient Conditions:

Temperature	33	[°C]	Altitude:	0	[m]	Humidity:	40	%
-------------	----	------	-----------	---	-----	-----------	----	---

Generating Set Rating:

Testing Full Load Current:	478.68	Amps	Nominal Current:	598.3	Amps
Power Correction Factor (De-rating):	0.000	%	Corrected Prime Power:	0.0	[kVA]

LOAD TEST

Load	Run Time	Freq	Speed	VOLTAGE L-L			CURRENT			Power	Coolant Temp	Oil Pressure	Charg-Alt.
				L1	L2	L3	L1	L2	L3				
%	min	Hz	RPM	V	V	V	A	A	A	kW	C	bar	VDC
0 %	5	60	1800	220	220	221	-	-	-	-	65	4.89	14.2
25 %	5	60	1800	220	220	221	118	118	118	45.0	70	4.75	14.2
50 %	5	60	1800	220	220	221	240	240	240	91.0	75	4.34	14.2
75 %	5	60	1800	220	221	222	358	358	358	137.0	80	4.04	14.2
100 %	10	60	1800	220	221	222	474	475	475	181.0	84	3.64	14.2
110 %	10	60	1800	220	221	222	525	526	525	201.0	89	3.44	14.2

LOAD ACCEPTANCE TEST


Suddenly Block Load %	Voltage [V]	Frequency [Hz]	Current [A]	Response Time [sec]
50%	220	60.0	240	0
0%	225 - 220	61.0 - 60.0	0	2
50%	213 - 220	58.1 - 60.0	242	2

PROTECTION SYSTEM TEST

Over Frequency Warning / SD	Under Frequency Warning / SD	Over Voltage Warning / SD	Under Voltage Warning / SD	Oil Pressure SD	Coolant Level SD	Coolant Temp Warning / SD
65 / 67	55 / 53	240 / 260	190 / 180	1.0	ECM OK	103 / 108 c

ACCESSORIES DETAILS

Model:		Serial No.	
Model:		Serial No.	



PI Document no. PI-TST-LT-01 Rev. 01