

SG-358-250

 Precision Industries Testing Department	GENERATING-SET LOAD TEST		Model No: PI 250 C		60 Hz
			Type: Close	Job No: 9522	
			Color: White	Date: 24/01/2019	

Serial Number:								
PI Model No:	PI 250 C	Prime Power:	228	[kVA]	P.F (Load):	1	Voltage:	220

Generating Set Details:

Engine:	Cummins	Model No: QSB7 - G5	Serial No: 84847398
Alternator:	Stamford	Model No: UCI 274 H1	Serial No: N18I396098
Controller:	DSE	Model No: 6120	Serial No: 6865750
C. Breaker:	Metasol	Model No: ABN 803C	Serial No: N/A
C.Transformer:	Ziegler 800/5A	Model No: N/A	Serial No: N/A
AVR:	Stamford	Model No: SX 460	Serial No: 113977 - 2561
Cooling System: Water Cool	Enclosure Type: Canopy	Protection Class: IP23	

Load Test Ambient Conditions:

Temperature	24	[°C]	Altitude:	0	[m]	Humidity:	54	%
-------------	----	------	-----------	---	-----	-----------	----	---

Generating Set Rating:

Testing Full Load Current:	478.68	Amps	Nominal Current:	598.3	Amps
Power Correction Factor (De-rating):	0.000	%	Corrected Prime Power:	0.0	[kVA]

LOAD TEST

Load	Run Time	Freq	Speed	VOLTAGE L-L			CURRENT			Power	Coolant Temp	Oil Pressure	Charg-Alt.
				L1	L2	L3	L1	L2	L3				
%	min	Hz	RPM	V	V	V	A	A	A	kW	C	bar	VDC
0 %	5	60	1800	220	220	220	-	-	-	-	47	5.04	13.8
25 %	5	60	1800	220	221	221	118	117	118	45.0	79	4.28	13.8
50 %	5	60	1800	220	221	221	240	239	240	92.0	82	3.84	13.8
75 %	5	60	1800	221	221	222	358	358	358	137.0	84	3.56	13.8
100 %	10	60	1800	221	221	222	479	480	480	184.0	85	3.40	13.8
110 %	10	60	1800	221	221	222	524	526	525	202.0	86	3.22	13.8

LOAD ACCEPTANCE TEST

Suddenly Block Load %	Voltage [V]	Frequency [Hz]	Current [A]	Response Time [sec]
50%	220	60.0	240	0
0%	224 - 220	61.4 - 60.0	0	2
50%	216 - 220	59.3 - 60.0	247	2

PROTECTION SYSTEM TEST

Over Frequency Warning / SD	Under Frequency Warning / SD	Over Voltage Warning / SD	Under Voltage Warning / SD	Oil Pressure SD	Coolant Level SD	Coolant Temp Warning / SD
65 / 67	55 / 53	240 / 260	190 / 180	1.0	ECM OK	103 / 108 c

ACCESSORIES DETAILS

Model:		Serial No.	
Model:		Serial No.	

TESTED
Testing Department

PI Document no.	PI-TST-LT-01	Rev.	01
-----------------	--------------	------	----