

SG-360-250



Power
Generation

Cummins India Ltd.

Power Generation Business Unit

Engine Test Certificate

QSB7-G5

This is to certify that Engine Model

84496040

Serial Numberwas tested using

Diesel as per ISO - 3046 Standard.

Corrected Full Load B.H.P to N.T.P conditions as per the

test standard is..... B.H.P.@.....R.P.M.
324BHP @ 1800RPM

Date : 29-Jun-18
/ /


Product Conformance

A048U279