

Certificate of Thorough Examination of Equipment

Name& address of Equipment owner		Location of inspection		Certificate No.	
Branch of Sudhir Gensets Limited		Dammam		IS0302204015	
ID NO.	Description of Equipment			SWL	Test Load
SG-339-60	GENERATOR Manufacturer : VARADA ENERGIES Serial No : VEPL/2018-19/0032 Capacity : 60 KVA			N/A	N/A
Date of Inspection :	28-Oct-20	Date Of Next Inspection :	27-Oct-21	Sticker No.	0048424
Scope of Work :	Visual inspection	Functional test	Load test	Ref. Standard	
	Pass	Pass	N/A	BS EN ISO 12100-1 & NFPA 110	

Inspection Details

Visual & Functional inspection have been applied for the above description and
Found satisfactory at Time of Inspection.

House keeping is required inside the generator to clean the floor from diesel .


Remarks (If Applicable) :

SAFE TO USE

TUV Rheinland Arabia certify that the item/s described herein were thoroughly examined and were found free from cracks , flaws, or other defects at the time of inspection unless otherwise stated above In remarks .

Inspector Name **Mohamed Hawana**

Signature




Checked by

Signature

