



الشركة العالمية لخدمات التفتيش المحدودة
UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت. ٢٠٥٥٠١١٦٤٣

CERTIFICATE OF INSPECTION

Certificate No: UIC/ALH/2029539

Customer : Sudhir Equipment Rental Company
Location : JGCP-5, Kingdom of Saudi Arabia.
Description : Power Generator
Make : Cummins
Model : 62.5
Serial No : 2023116251
Capacity : 50/62.5 KW/ kVA
ID. No. : SG-1036-60

This is to certify that the equipment detailed hereby has been inspected and found satisfactory against traceable International Standards for its function on the date of inspection. These conform to manufacturer's specification and have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise noted below, conform in all respects to the specifications relevant here to.

Date of Inspection: 02-Feb-2025

Due Date: 01-Aug-2025

Additional Certification

Sticker Number: 217863

Inspected By:



Industrial Inspector



Approved By:

S. Zuy
QA/QC Engineer

P.O. Box No. 2072, Jubail - 31951, K.S.A.
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881
Tel.: +966 13 367 0515

www.ui.com.sa

ص. ب ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية
هاتف ٨٨٨٢ ١٣ ٩٦٦ / فاكس ٨٨٨١ ١٣ ٩٦٦
هاتف ٠٥١٥ ٣٦٧ ١٣ ٩٦٦

Certificate No: UIC/ALH/2029539**Specification:**

Rated Power	: 62.5 kVA	-	Power Factor	: 0.8
Rated Current	: 940 AMP	-	Rated Voltage	: 380/220Volts
Rated Ambient	: 40 °C	-	Speed	: 1800 Rpm
Engine Model	: 4BTAA3.3-G11	-	Weight	: 1500 Kg
Year	: 2023			

Reference Standards

- : BS 5000 Part 3 IEC 34-1
- : Nema MG 1-3L ISO 8528-3

Inspection and Test:

Internal Visual Test	: Satisfactory	-	General Surface Test	: Satisfactory
Compressor Shut-Down	: Satisfactory			

Comments & Recommendations:

The **Generator** was found to be of good working condition and reliable for safe operation.

1. Do not exceed the capacity of the Generator.
2. Inspect the Generator regularly for damage before every use.
3. Check the operating characteristic before start the Generator.
4. Unless otherwise specified, all maintenance and service must be carried out the engine Stopped.

5. Remember - Safety always comes first!

Inspected By:

34
Industrial Inspector



Approved By:

S. Zaky
QA/QC Engineer