

VARADA ENERGIES PVT LTD., Dist - Pune

Works: Land+Building/Shed No-3, Milkat No-950 & GAT No- 712 / 713, Pune Satara Road, Velu Phata, Village- velu, Tehsil- Bhor, Dist - Pune.

TEST CERTIFICATE

FOR

SALIENT POLE,SELF EXCITED/ PMG EXCITED AND SELF REGULATED AC GENERATOR

Machine No -N16J434792

Type Test has been conducted on similar design machine

STANDARDS- Generator conforms to BS 5000 : Part-3, IS 4722

Tested in accordance with BS EN 60034-1

Rotor dymanically balanced to BS ISO 1940-1

ROUTINE TEST CERTIFICATE FOR BRUSHLESS AC GENERATOR

FRAME	AVR : SX460	AVR NO : 1097300055	ENCLOSURE : IP 23	PHASE : 3
RATED Kva- 160	RATED VOLTS : 400	RATED AMPS :	FREQUENCY : 60	WIRE : 4- wire
POWER FACTOR- 0.8	STR CONN : Star	STAR WINDING : 311	RATING : CONTINUOUS	
EXC. VOLTS- 68	EXC. AMPS : 2.3	AMB TEMP : 40		

FOR 3 PHASE SEQUENCE LOOKING FROM DRIVE END		FOR CLOCKWISE ROTATION : U-V-W	
WINDING	COLD RESISTANCE IN Ohm (+/-10) AT 20 DEG CEN (MAX VALUES)	INSULATION RESISTANCE (M-Ohm)	HV TEST 2 KV FOR 1 MIN
STATOR	0.05566	2+	OK
ROTOR	1.617	2+	OK

REGULATION TEST									
FREQ	VOLTS	AMPS	kVA	PF	KW	EXC VOLT	EXC AMP	% LOAD	
62	401.4	0	0	0	0	11	0.45	0	
60.00	400	178	160	0.8	128	58.0	2.3	100	

REGULATION + (N.L. VOLTAGE -F.L. VOLTAGE / RATED VOLTAGE) * 100=0.34 %

ITEM DESCRIPTION : AC GENERATOR UC27.4.F.1.311.2..11.5..SX-460. BLACK RAL9011

DATE	JOB NO-	AUTHORISED SIGNATORY
------	---------	----------------------

CRTIFICATE OF CONFORMITY
QUALITY SYSTEM APPROVAL

[Signature]


AUTHORISED SIGNATORY Q.C

FRAME SIZE : UC1274F1

SERIAL NUMBER : N16J434792

KVA : 160

ELECTRICAL TEST - KHUSIYAL



[Signature]

MANUFACTURED DATE : 03/02/2017

FINAL INSPECTION - MOHAN

DATE - 03/02/17

VARADA ENERGIES PVT LTD.

ENGINE TEST CERTIFICATE

This is to certify that Engine Model.....AL6DTIG4


Serial Number GVHM433102 was tested using

Diesel as Per ISO-3046 Standard.

Corrected Full Load B.H.P. to N.T.P. conditions as per the

Test standard is 218 H.P. @ 1800 R.P.M.

Date - 15/01/2017



S. P. Joshi
Product Conformance