

CERTIFICATE OF THOROUGH EXAMINATION OF DIESEL GENERATOR

Date of thorough examination : 29-07-2025		Date of issue : 29-07-2025		Report No. : ESICO-LFT-R25-4965	
Name & Address of employer			Location	Sticker No	Standards
SUDHIR EQUIPMENT RENTALS COMAPNY			Riyadh	6617	SASO ISO 12100
Equipment Identification No	Equipment Description		Safe Working Load(s)	Date of Manufacture	Manufacturer Name
SG-1287-60 OR PW62-5M3H25-01781	GENERATOR MODEL: DG.62.5M3.S.E.B193 Rated power(KVA):62.5 Rated power factor: 0.8 Rated voltage: 400 Rated frequency: 60 Rated current(A): 90		WEIGHT: 1293KG	2025	MAHINDRA
Is this the first examination after installaton or assembly at a new site or location? Yes ☒ No ☐			Was the examination carried out within an interval of? - 6 Months In accordance with an examination scheme? Yes ☒ No ☐		
If the answer to the above question is YES, has the equipment been installed correctly? Yes ☒ No ☐			After the occurence of exceptional circumstances? Yes ☐ No ☒		
Identification of any part found to have a defect which is or could become a danger to persons and a description of the defect (if none state NONE) : NONE					
Is the above an existing or imminent danger to persons, Note: This is a reportable defect?					N/A
Is the above a defect which is not yet could become a danger to persons (if YES state the date by when)			Yes by : N/A		
Particulars of any repair, renewal or alteration required to remedy the defect identified above : N/A					
Particulars of any tests carried out as part of the examination (if none state NONE) : NONE					
Observation/additional comments relative to this thorough examination : At the time of inspection generator was found to be of good condition and reliable for safe operation					



For confirmation scan QR code
search with report number : **ESICO-LFT-R25-4965**



☒ **Safe to operate**

Next Inspection : 28-01-2026

Inspected by : Mohamed Askar Ali

