



INSPECTION REPORT

NO. R110210909.01

☐ Interim
☒ Final

BV Job nr: KHO.INI.19.206.SA.

PROJECT: Third Party Inspection for GENERATOR	Ref: KHO.INI.19.206.SA
BV Client: Sudhir Rentals	P/o nr: N/A (client to BV)
Manufacturer: SUDHIR POWER LTD /CUMMINS	

SUPPLY / SUBJECT OF INSPECTION	SN / TAG Nr	Owner ID No	QTY
VISUAL EXAMINATION AND FUNCTIONAL TEST OF GENERATOR	1704B273	SG-130-125	1

DOCUMENTS OF REFERENCE : See continuation sheet for additional documents: ☐ Yes ☐ No

Title	Reference n°	Rev.	Approved by	Date
EQUIPMENT DATA SHEET	-	-	SUDHIR	-

INSPECTIONS :**Inspection place & Date or Period:**

DAMMAM SUDHIR YARD.
SEP 09, 2021

Stage of inspection :

- ☐ Before manufacturing
☐ During manufacturing
☒ Final
☐ Packing

Type of inspection:

- ☐ Pre-inspection meeting
☐ Document and QC record review
☒ Visual examination, checks
☐ Witnessing tests
☐ Manufacturing progress status
☐ Vendor assessment
☒ Final inspection
☐ Packing

(for details see continuation sheet)

Stamping:

☒ No ☐  ☐ 

Results of inspection : ☒ Satisfactory ☐ Unsatisfactory**Non Conformities Reports (NCR):**

- o NCR's issued during reported period : N/A
 o List of outstanding NCR's : N/A

Main Conclusions & Remarks: (for details see continuation sheet)

Third party visual inspection and functional test of one unit of Generator was carried out and found satisfactory at the time of Inspection.

Valid Sticker Number : LTF-S-01-26877**Next visit scheduled:** SEP 08, 2022



INSPECTION REPORT

NO. R110210909.01

☐ Interim
☒ Final

BV Job nr: KHO.INI.19.206.SA.

Description of the inspections carried out:**1. Introduction:**

The undersigned surveyor to Bureau Veritas acting within the scope of work along with the General condition which Regulate the intervention of the society IVS Department at the Request of Sudhir Rental Co. on the purpose of Third Party Inspection.

2. Scope of Inspection :

Visual Inspection & Functional Test of Generator.

1- General Data

Equipment Type	Generator
Manufacturer	Sudhir Power LTD / CUMMINS
Model	CS125D5P
Serial No.	1704B273
Alternator No	N17D166248
Owner ID No	SG-130-125
Rating	125 kVA

3- Inspection and Test Results

Acceptance criteria	Result	Remarks
1. Document review (Original Declaration of Conformity)	Pass	Available
2. Visual inspection of Unit-leaks, wear, damage, loose connection/components, corrosion.	Pass	Found good condition.
3. Check air filter and engine oil level	Pass	Found good condition.

➤ Conclusion:

The Generator was found satisfactory and in good running condition at the time of Inspection.

Surveyor's name: Ahmed ZoneFull

Signature:



Issued at Al Khobar office on 09 SEP 2021

Authorized by team leader :

Signature: