



REPORT OF INSPECTION

Cert. No.: 2148239	Date of Examination: 25/01/2026	Sticker No.: 01-90135
Equipment Owner	Sudhir Equipment Rental Company	
Place of Inspection	Dammam Yard	
Equipment Type	Portable Diesel Generator.	
Manufacturer Name	Chuangyuan Power	
Owner ID	SG-1312-150	
Serial No.	2504042-4	
Model	CY150	
Rated Power	150 kVA	
Voltage / Frequency	480 V / 60 HZ	
Speed	1800 RPM	

At the request of Sudhir Equipment Rental Company, Surveyor to BUREAU VERITAS, acting within the General Conditions of Services of the Society, attended on 25/01/2026 at Dammam Yard to witness Test and/or to carry out Thorough Examination of the above-mentioned equipment as per ISO 8528.

Inspection Activities:

Prior to commencing performance test, visual inspection of the equipment was carried out and no visible defects were observed. The equipment was then operated to all the functions to verify the performance of the equipment.

Result of Inspection:

Based on the visual inspection of the Portable Diesel Generator. and upon post-performance test & thorough examination, the above mentioned equipment has been found free from damage and/or permanent deformation at the time of inspection & is considered to be safe for further use, subject to continuous maintenance being applied and qualified operator being employed.

Remarks:

- Maintain regular maintenance.
- Maintain regular housekeeping

Next Inspection Due on or before: 24/07/2026

Issued at Al Khobar on 26/01/2026

Inspected by

Signature:



Name: Mohamed Elsabry
Position: Inspector



Reviewed by
Signature:



Name: Ahmed Elabady
Position: Reviewer

The technical conclusions thus expressed may have to be reconsidered in light of any modifications or alterations that would invalidate the data shown in the present certificate. These conclusions would become null & void should Bureau Veritas not be kept informed of such modifications or alterations with specific reference to the present certificate.

Any person not a party to the contract pursuant to which this document is delivered may not assert a claim against Bureau Veritas for any liability arising out of errors or omissions which may be contained in said document, or for errors of judgement, fault or negligence committed by the personnel of the Society or of its Agents in the establishment or issuance of this document, and in connection with any activities for which it may provide.

This not is NOT an indication that the item(s) is (are) fit for any specific purpose and does not release the manufacture, supplier and any party from their respective duty, guarantee, obligation and/or indemnity relating to, without limitation patents, workmanship, materials, safety, performance in operation and/or reliability.



CHECKLIST OF TEST & THOROUGH EXAMINATION

Inspection Sticker No.:01-90135		Date of Examination:25/01/2026
DESCRIPTION		CONDITION/REMARKS
1.	Physical condition of the equipment	Satisfactory
2.	Condition of the display panel / gauges	Satisfactory
3.	Visibility & functionality of the emergency stop button	Satisfactory
4.	Condition of the generator door	Satisfactory
5.	Condition of the power supply panel	Satisfactory
6.	Condition of the diesel tank	Satisfactory
7.	Indication of any leakage observed	Satisfactory
8.	Any unnecessary vibration observed	Satisfactory
9.	Placement / Environment of the generator	Satisfactory
10.	Ventilation condition	Satisfactory
11.	Availability of suitable fire extinguisher and/or sand	Satisfactory
12.	Insulation rubber mat at all panels / gauges	Satisfactory
13.	Markings / Labels & warning signage	Satisfactory
14.	Spill observant kit or drip tray	Satisfactory
15.	Electrical grounding condition	Satisfactory
16.	Condition of the skid	Satisfactory
17.	Name plate	Satisfactory
Remarks: FIT FOR PURPOSE		

Inspector to Bureau Veritas
Signature:




Name: Mohamed Elsabry
Position: Inspector

The technical conclusions thus expressed may have to be reconsidered in light of any modifications or alterations that would invalidate the data shown in the present certificate. These conclusions would become null & void should Bureau Veritas not be kept informed of such modifications or alterations with specific reference to the present certificate.

Any person not a party to the contract pursuant to which this document is delivered may not assert a claim against Bureau Veritas for any liability arising out of errors or omissions which may be contained in said document, or for errors of judgement, fault or negligence committed by the personnel of the Society or of its Agents in the establishment or issuance of this document, and in connection with any activities for which it may provide.

This not is NOT an indication that the item(s) is (are) fit for any specific purpose and does not release the manufacture, supplier and any party from their respective duty, guarantee, obligation and/or indemnity relating to, without limitation patents, workmanship, materials, safety, performance in operation and/or reliability.

