

Certificate of Visual Examination

Client Name :		
SUDHIR EQUIPMENT RENTAL COMPANY		
Work/ Rig Location:	Certificate Number:	Issued Sticker No.(if Applicable)
DMM yard	ZM-20-Z085- 99	W.4329
Date of Last Inspection	Date of Inspection:	Date of Next Inspection:
BRAND NEW	19-Nov-2020	18-Nov-2021
Relevant Standards:	O.E.M / C.O.C / Reverse Engineering Cert. No.	Color Code (If Applicable for the item) (Current applicable Color at the Time of Inspection)
ISO 8528-3:2020	Manufacturer Manual	
Zamil Ref No.	Customer Requisition No.	N/A
ZAM-2336-11-20	SG-EPO-2020-0148	

I.D. NUMBER	QTY	DESCRIPTION	SWL / CAPACITY
STL-034	01	TOWER LIGHT MANUFACTURER : WACKER NEUSON-2020 MODEL : LTS8K S/N : 18201322 NOTE : Visual Inspection & Functional Test Were Carried Out On The Above Mentioned Equipment , At The Time Of Inspection No Any Abnormality Found.	8 KVA

Result: During the Time of Visual Inspection, Result found Satisfactory.

This Certificate by Company Under Its General Conditions of Services. This Issuance of This Certificate Does Not Exonerate the Buyers or Sellers from Exercising All Their Rights Discharging All Their Liabilities Under the Contacts of Sale. Stipulations to Contrary Are Not Binding On The Companies Responsibility Under This Certificates Is Limited to Proven Negligence and Will in No Case Be More Than Ten Times the Amount of The Free or Commission. The Above Findings Are Limited to Date Place of Intervention Only. The Company Is Neither an Insurer Not a Guarantor Disclaims All Liabilities in Such Capabilities.

Inspected By:
Name : HASSAN ALGUDAIHI
Qualifications : LEEA & ASNT NDT Level II Certified

Signature & Stamp:





طريق الملك فهد - حي الضباب - الدمام - س.ت: 2050069798 - ص.ب. 419 - آدما 31411

King Fahad Road - Al-Dhabab Avenue - Dammam - C.R.: 2050069798 - P.O. Box 419 - Dammam 31411 Email: info@zamil.sa

Generator Inspection Checklist

I.D Number	STL-034	Equipment Description	DIESEL POWERD TOWER LIGHT
Report No.	ZM-20-Z085-99	Manufacturer	WACKER NEWSON-2020
Inspection Date	19-Nov-20	Client	SUDHIR EQUIPMENT RENTAL COMPANY

ITEM No.	ACCEPTANCE CRITERIA	PASS	FAIL	N/A
A	GENERAL REQUIREMENTS			
1	Document Review (Original Declaration Of Conformity).	✓		
2	Previous Inspection reports are checked	✓		
3	Manufacturer name, address, serial number, are clearly tagged or marked	✓		
4	Visual Inspection Of Unit-Leaks, Wear, Damage, Loose Connection / Components & Corrosion.	✓		
5	Check Engine Oil Level (Check For Proper Oil Level).	✓		
6	Controls are marked of its function	✓		
7	Check For Descending Output (Rated Power (KW), Rated Current (DCA), Rated Voltage (DCV), Idle Voltage (DCV) & Rated Duty Cycle%.	✓		
8	Checked For Engine Filter And Oil Level.	✓		
9	Checked For Accessorial Receptacle.	✓		

Conclusion:

The Generator Found In Good Running Condition At The Time Of Inspection.

Inspected by: HASSAN ALGUDAIHI

Stamp & Signature:


