



الشركة العالمية لخدمات التفتيش المحدودة UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س. ت ١١٦٤٣ ٢٠٥٥

THOROUGH EXAMINATION CERTIFICATE OF GENERATOR

Report No:	ALH-INS-2026-09-08224	Report Issue Date:	04-Sep-2026
Customer Name:	Sudhir Equipment Rental Company	Inspection Type:	Visual Inspection
Address:	king faisal road	Serial Number	PW62.5M3T25.03290
Site Location:	GOSP-5	Equipment Id Number:	SG-1614-60
Standard Reference:	ISO 8528-5:2022	Manufacturer:	MAHINDRA
Inspection Date:	31-Aug-2026	Equipment Model/Type:	DG.62.5M3.S.E.B193
Next Inspection Date:	28-Feb-2027	Sticker No:	ALH/006334

Description		Capacity/SWL	Reason For Examination	Result	Safe To Use
Rated Power	60 KVA	N/A	B	Satisfactory	YES
Rated Voltage	400 V				
Rated Speed	1800 RPM				
Phase& Power Factor	3 & 0.8Φ				
Fluid Levels & Systems	Satisfactory				
Electrical & Battery	Satisfactory				
Control Panel & Grounding	Satisfactory				
Mechanical & Physical Condition	Satisfactory				
Emergency stop button	Satisfactory				
Fire extinguisher	Satisfactory				
Internal Visual Test	Satisfactory				
General Surface Test	Satisfactory				

Reason For Exam.	A 3 Months	B 6 Months	C 12 Months	D Written Scheme	E Exceptional Circumstance	F Installation
------------------	---------------	---------------	----------------	---------------------	-------------------------------	-------------------

Result	ACCEPTED	REJECTED (See Attached Defect Report)
--------	----------	--

Declaration:

I hereby declare that the above information is correct and that the equipment has been thoroughly examined as far as possible in accordance with the appropriate provisions/Standards that at the time of the Inspection/examination and found to be free from any defect likely to affect safety other than theses detailed above.

Inspected By:		Approved By:	Signature:
Stamp By:		BOWJUL KHAN	
		Designation:	
		Inspection Supervisor	

No liability will be considered against UNIVERSAL INSPECTION COMPANY for failure, damage or other occurrence of Client owned or operated equipment due to misuse, improper installations, poor maintenance, weather/environmental conditions & equipment operator/user mistakes or uncontrolled operation & maintenance. This Inspection Certificate/Report shall not be reproduced except in full without the approval UIC and the Client.

أرامكو السعودية
saudi oramco
VENDOR ID: 1004457

THE RED SEA
The Red Sea
APPROVED VENDOR

سابك
SABIC
VENDOR ID: 11052442

الشركة السعودية للكهرباء
Saudi Electricity Company
VENDOR ID: 5014041

معدن
MA'ADEN
VENDOR ID: 10857

P.O Box no. 2072, Jubail-31951, KSA
Tel.: +966 13 344 8882/Fax.: +966 13 344 8881
Tel.: +966 13 367 0515
Website: www.ui.com.sa



For Verification of This Report Scan Above QR Code:

The PDF document is electronically generated and digitally signed

ص. ب ٢٠٧٢ ، الجبيل ٣١٩٥١ - المملكة العربية السعودية
+966 13 344 8882 / فاكس: +966 13 344 8881
+966 13 367 0515
الموقع الإلكتروني: www.ui.com.sa
Doc No. UIC FMT 091-E/Rev No.-00