



الشركة العالمية لخدمات التفتيش المحدودة

UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت ٢٠٥٥٠١١٦٤٣

INSTRUMENT & EQUIPMENT CALIBRATION DIVISION

CERTIFICATE OF CALIBRATION

CERTIFICATE NO: UIC/ALH/54504

This certifies that the instrument below has been tested/calibrated using equipment traceable to National/International Standards or verified by ratio type measurements using self calibrating techniques.

Information on the calibration process and the results are produced below and given in the accompanying sheets of this document.

All related traceable documents are on file at **UNIVERSAL INSPECTION CO. LTD.** and may be examined on request

Customer **Sudhir Equipment Rental Company**
Location Abqaiq, Kingdom of Saudi Arabia

Description **Pressure Relief Valve**
Manufacturer SAFETY VALVE
Type AK28X-16T
Serial No. 250166
ID. No. SAC-850-414
Location Calibration Lab (Al Hasa)

Receipt Date : 3-Sep-26
Calibration Date : 3-Sep-26
Calibration Due Date : 2-Mar-27

The instrument was calibrated using the following reference, maintained at UIC Instrument & Equipment Calibration division conforming to ISO/IEC 17025:2017 requirements

Reference Standard Equipment Used

Description	Model / Cert. No.	Serial No	Due Date
High Pressure Pneumatic Pressure Source	SA178189-227063	214E2207012	27-Apr-27
Digital Pressure Calibrator	SA178189-227064	223210304	27-Apr-27

Calibrated By

89
Calibration Engineer

Approved By

QA/QC Engineer

UIC-QP-7.8-24 E02, REV 0

The measurement results pertain only to the instrument calibrated.

This certificate and the attached measurement result sheets shall not be reproduced except in full without the prior permission

P.O. Box No. 2072, Jubail - 31951, K.S.A.
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881
Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية
هاتف ٩٦٦ ١٣ ٣٤٤ ٨٨٨٢ / فاكس ٩٦٦ ١٣ ٣٤٤ ٨٨٨١
هاتف ٩٦٦ ١٣ ٣٦٧ ٠٥١٥

CERTIFICATE NO: UIC/ALH/54504		Page 2 of 2
Customer	Sudhir Equipment Rental Company	
Location	Abqaiq, Kingdom of Saudi Arabia	
Description	Pressure Relief Valve	
Manufacturer	SAFETY VALVE	Calibration Date 3-Sep-26
Model	AK28X-16T	Calibration Due Date 2-Mar-27
Serial No.	250166	Temperature Range 23.5°C
ID. No.	SAC-850-414	Relative Humidity RH 47%
<u>Test Results</u>		
Set Pressure :	12.00 BAR	Maximum Pressure : N/A
Back Pressure :	0.00 BAR	Size Inlet/Outlet : 1" x 2"
CDTP :	12.00 BAR	Type of Valve : Metal Seated
Setting Accuracy :	± 3 % of Setting	Test Medium : AIR
Pop Test : PASSED		
<u>BASIS OF TEST:</u>		
Ref Standard ASME Sec VIII, Div I		
<u>Summary of Test Procedure:</u>		
The Calibration of above Pressure relief valve is performed through the verification of set pressure and seat tightness using a reference standard pressure gauge or test gauge and a hydrostatic / pneumatic test system.		
<u>Traceability:</u>		
The reported tests were undertaken using equipment detailed mentioned in Reference Standard Equipment's for which the company maintains Traceability to the third party.		
<u>Condition of Instrument</u>		
With in the tolerance on receipt(as found)	Yes	
The instrument was adjusted	No	
The instrument was repaired	No	
++++ End of the Certificate +++++		
 Calibrated By: _____ Calibration Engineer	 UIC-QP-7.8-24 E02, REV.0	Approved by: _____ QA/QC Engineer