



الشركة العالمية لخدمات التفتيش المحدودة UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت ٢٠٥٥٠١١٦٤٣

INSTRUMENT & EQUIPMENT CALIBRATION DIVISION

CERTIFICATE OF CALIBRATION

CERTIFICATE NO: UIC/DAM/29986

This certifies that the instrument below has been tested/calibrated using equipment traceable to National/International Standards or verified by ratio type measurements using self calibrating techniques.

Information on the calibration process and the results are produced below and given in the accompanying sheets of this document.

All related traceable documents are on file at **UNIVERSAL INSPECTION CO. LTD.** and may be examined on request

Customer	Sudhir Equipment Rental Company		
Location	Dammam, Kingdom of Saudi Arabia		
Description	Pressure Relief Valve		
Manufacturer	Safety Valve		
Part No.	AK28X-50T		
Serial No.	210395	Receipt Date	23-Apr-24
ID. No.	SAC-350-006	Calibration Date	23-Apr-24
Location	Calibration Lab (Dammam)	Calibration Due Date	22-Oct-24

The instrument was calibrated using the following reference, maintained at UIC Instrument & Equipment Calibration division conforming to ISO 17025 requirements


Reference Standard Equipment Used

Description	Model / Cert. No.	Serial No	Due Date
High Pressure Pneumatic Pressure Source	2024001135	2000E2208001	18-Feb-25
Digital Pressure Calibrator	2024001136	2232209002	13-Feb-25

Calibrated By



Calibration Engineer



UIC-QP-7.8-24 F02, REV 0

Approved By

Signature

QA/QC Engineer

The measurement results pertain only to the instrument calibrated.

This certificate and the attached measurement result sheets shall not be reproduced except in full without the prior permission

P.O. Box No. 2072, Jubail - 31951, K.S.A.

Tel.: +966 13 344 8882 / Fax: +966 13 344 8881

Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية

هاتف ٩٦٦ ١٣ ٣٤٤ ٨٨٨٢ / فاكس ٩٦٦ ١٣ ٣٤٤ ٨٨٨١

هاتف ٩٦٦ ١٣ ٣٦٧ ٠٥١٥

CERTIFICATE NO: UIC/DAM/29986

Page

2 of 2

Customer Address **Sudhir Equipment Rental Company**
Dammam, Kingdom of Saudi Arabia

Description **Pressure Relief Valve**

Manufacturer Safety Valve

Model AK28X-50T

Serial No. 210395

ID. No. SAC-350-006

Calibration Date 23-Apr-24

Calibration Due Date 22-Oct-24

Temperature Range 23.5°C

Relative Humidity RH 47%

Test Results

Set Pressure : 11.80 Bar

Spring Range : N/A

Back Pressure : 0.00 Bar

Size Inlet / Outlet : 3/4" x 1 1/4"

CDTP : 11.80 Bar

Type of Valve : Metal Seated

Setting Accuracy : $\pm 3\%$ of Setting

Pop Test : PASSED

Test Medium : Air/Water/Oil/Gas

BASIS OF TEST:

Ref Standard ASME Sec VIII, Div I

Summary of Test Procedure:

The Calibration of above Pressure relief valve is performed through the verification of set pressure and seat tightness using a reference standard pressure gauge or test gauge and a hydrostatic / pneumatic test system.

Traceability:

The reported tests were undertaken using equipment detailed mentioned in Reference Standard Equipment's for which the company maintains Traceability to the third party.

Condition of Instrument

With in the tolerance on receipt(as found)

No

The instrument was adjusted

Yes

The instrument was repaired

No

++++ End of the Certificate +++++

Calibrated By:



Calibration Engineer

UIC-QP-7.8-24 F02, REV 0

Approved by:

For:

QA/QC Engineer