



الشركة العالمية لخدمات التفتيش المحدودة UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت ٢٠٥٥٠١١٦٤٣

INSTRUMENT & EQUIPMENT CALIBRATION DIVISION

CERTIFICATE OF CALIBRATION

CERTIFICATE NO: UIC/DAM/51783

This certifies that the instrument below has been tested/calibrated using equipment traceable to National/International Standards or verified by ratio type measurements using self calibrating techniques.

Information on the calibration process and the results are produced below and given in the accompanying sheets of this document.

All related traceable documents are on file at **UNIVERSAL INSPECTION CO. LTD.** and may be examined on request

Customer	Sudhir Equipment Rental Company		
Location	Dammam, Kingdom of Saudi Arabia		
Description	Pressure Relief Valve		
Manufacturer	Safety Valve		
Type	AK28X-50T		
Serial No.	210377	Receipt Date	10-Mar-25
ID. No.	SAC-350-010	Calibration Date	10-Mar-25
Location	Calibration Lab (Dammam)	Calibration Due Date	09-Sep-25

The instrument was calibrated using the following reference, maintained at UIC Instrument & Equipment Calibration division conforming to ISO 17025 requirements

Reference Standard Equipment Used

Description	Model / Cert. No.	Serial No	Due Date
High Pressure Pneumatic Pressure Source	SA 178189-210065	214E191209	23-Apr-25
Digital Pressure Calibrator	SA 178189-210066	23162191108	23-Apr-25

Calibrated By

Calibration Engineer



Approved By

QA/QC Engineer

The measurement results pertain only to the instrument calibrated.

This certificate and the attached measurement result sheets shall not be reproduced except in full without the prior permission

P.O. Box No. 2072, Jubail - 31951, K.S.A.

Tel.: +966 13 344 8882 / Fax: +966 13 344 8881

Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية

هاتف ٩٦٦ ١٣ ٣٤٤ ٨٨٨٢ / فاكس ٩٦٦ ١٣ ٣٤٤ ٨٨٨١

هاتف ٩٦٦ ١٣ ٣٦٧ ٠٥١٥

CERTIFICATE NO: UIC/DAM/51783

Page 2 of 2

Customer **Sudhir Equipment Rental Company**
Location Dammam, Kingdom of Saudi Arabia

Description **Pressure Relief Valve**

Manufacturer Safety Valve

Model AK28X-50T

Serial No. 210377

ID. No. SAC-350-010

Calibration Date 10-Mar-25

Calibration Due Date 09-Sep-25

Temperature Range 24.2°C

Relative Humidity RH 49%

Test Results

Set Pressure	:	12.00	BAR	Spring Range	:	N/A
Back Pressure	:	0.00	BAR	Size Inlet/Outlet	:	3/4"
CDTP	:	12.00	BAR	Type of Valve	:	Metal Seated
Setting Accuracy	:	± 3 % of Setting		Test Medium	:	Air
Pop Test : PASSED						

BASIS OF TEST:

Ref Standard ASME Sec VIII, Div I

Summary of Test Procedure:

The Calibration of above Pressure relief valve is performed through the verification of set pressure and seat tightness using a reference standard pressure gauge or test gauge and a hydrostatic / pneumatic test system.

Traceability:

The reported tests were undertaken using equipment detailed mentioned in Reference Standard Equipment's for which the company maintains Traceability to the third party.

Condition of Instrument

With in the tolerance on receipt(as found)	No
The instrument was adjusted	Yes
The instrument was repaired	No

++++ End of the Certificate +++++



Calibrated By: _____
 Calibration Engineer



UIC-QP-7.8-24 F02, REV 0

Approved by: _____
 QA/QC Engineer