



الشركة العالمية لخدمات التفتيش المحدودة UNIVERSAL INSPECTION CO. LTD.

CR No.2055011643

س.ت. ١١٦٤٣ ٢٠٥٥

INSTRUMENT & EQUIPMENT CALIBRATION DIVISION

CERTIFICATE OF CALIBRATION

CERTIFICATE NO: UIC / TUR / 24116

This certifies that the instrument below has been tested/calibrated using equipment traceable to National/International Standards or verified by ratio type measurements using self calibrating techniques.

Information on the calibration process and the results are produced below and given in the accompanying sheets of this document.

All related traceable documents are on file at **UNIVERSAL INSPECTION CO. LTD.** and may be examined on request

Customer	Grey Line Contacting Company		
Address	Al-Turaif, Kingdom of Saudi Arabia		
Description	Pressure Relief Valve		
Manufacturer	DOOSAN		
Part No./Type	54731450		
Serial No.	N/A		
ID. No.	SAC-435-023	Calibration Date	10-Jan-26
Location	Calibration Lab (Turaif)	Calibration Due Date	09-Jul-26

The instrument was calibrated using the following reference, maintained at UIC Instrument & Equipment Calibration division conforming to ISO 17025 requirements

Reference Standard Equipment Used

Description	Cert. No./Model	Serial No	Due Date
PORTABLE HIGH PRESSURE PNEUMATIC HAND PUMP	VIC-25-42537	2011H13013	18-Sep-26
DIGITAL PRESSURE GAUGE	VIC-25-57999	S132001185	18-Sep-26

Calibrated By



Approved By

[Signature]
QA/QC Engineer

The measurement results pertain only to the instrument calibrated.

This certificate and the attached measurement result sheets shall not be reproduced except in full without the prior permission

P.O. Box No. 2072, Jubail - 31951, K.S.A.

Tel.: +966 13 344 8882 / Fax: +966 13 344 8881

Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب. ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية

هاتف ٨٨٨٢ ١٣ ٩٦٦ / فاكس ٨٨٨١ ١٣ ٩٦٦

هاتف ٥١٥ ١٣ ٣٦٧ ٩٦٦

CERTIFICATE NO: UIC / TUR / 24116

Customer **Grey Line Contacting Company**
Address Al-Turaif, Kingdom of Saudi Arabia

Description	Pressure Relief Valve	Calibration Date	10-Jan-26
Manufacturer	DOOSAN	Calibration Due Date	09-Jul-26
Part No.	54731450	Lab Temperature	22°C
Serial No.	N/A	Lab Relative Humidity	45%
ID. No.	SAC-435-023		

Test Results

Set Pressure : 14.00 bar	Spring Range : -----
Back Pressure : 0 bar	Size Inlet : 3/4" X 1"
CDTP : 14.00 bar	Type of Valve : Metal Seated
Setting Accuracy : ± 3 % of Setting	Test Medium : Air
Pop Test : PASSED	

BASIS OF TEST:

Ref Standard ASME Sec VIII, Div I

Summary of Test Procedure:

The Calibration of above Pressure relief valve is performed through the verification of set pressure using a reference standard pressure gauge or test gauge and a hydrostatic / pneumatic test system.

Traceability:

The reported tests were undertaken using equipment detailed below for which the company maintains Traceability to the third party.

Condition of Instrument

With in the tolerance on receipt(as found)	No
The instrument was adjusted	No
The instrument was repaired	No


Calibrated By:


 Calibration Engineer



UIC-QP-7.8-24 F02, REV 0

Approved by:


 QA/QC Engineer