



الشركة العالمية لخدمات التفتيش المحدودة UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت ٢٠٥٥٠١١٦٤٣

INSTRUMENT & EQUIPMENT CALIBRATION DIVISION

CERTIFICATE OF CALIBRATION

CERTIFICATE NO : UIC/RIY/36429

This certifies that the instrument below has been tested/calibrated using equipment traceable to National/International Standards or verified by ratio type measurements using self calibrating techniques.

Information on the calibration process and the results are produced below and given in the accompanying sheets of this document.

All related traceable documents are on file at **UNIVERSAL INSPECTION CO. LTD.** and may be examined on request

Customer	Sudhir Equipment Rental Company.		
Address	Dammam, Kingdom of Saudi Arabia		
Description	Pressure Relief Valve		
Manufacturer	AFS	Receipt Date	: 19-Nov-25
Model	AK28X-50T	Calibration Date	: 19-Nov-25
Serial No.	220094	Report Date	: 19-Nov-25
Id No.	N/A	Issue date	: 19-Nov-25
Location	Calibration Lab	Calibration Due Date	: 18-May-26

The instrument was calibrated using the following reference, maintained at UIC Instrument & Equipment Calibration division conforming to ISO 17025 requirements

Reference Standard Equipment Used


Description	Model / Cert. No.	Serial No.	Due Date
Water Pressure Comparator	VIC-25-42247	990S2412008	04-May-26
Digital Pressure Gauge	VIC-25-57095	2232412038	04-May-26

Calibrated By

Calibration Engineer



UIC-OP-7.8.2-17, REV 02

Approved By

QA/QC Engineer

The measurement results pertain only to the instrument calibrated.

This certificate and the attached measurement result sheets shall not be reproduced except in full without the prior permission

P.O. Box No. 2072, Jubail - 31951, K.S.A.
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881
Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية
هاتف ٩٦٦ ١٣ ٣٤٤ ٨٨٨٢ / فاكس ٩٦٦ ١٣ ٣٤٤ ٨٨٨١
هاتف ٩٦٦ ١٣ ٣٦٧ ٠٥١٥

CERTIFICATE NO : UIC/RIY/36429

Customer
Address**Sudhir Equipment Rental Company.**

Dammam, Kingdom of Saudi Arabia

Description

Pressure Relief Valve

Manufacturer

AFS

Model

AK28X-50T

Serial No.

220094

Id No.

N/A

Calibration Date

19-Nov-25

Calibration Due Date

18-May-26

Temperature

23.0 ± 2°C

Relative Humidity

RH 45% to 75%

Test Results

Set Pressure : 16.0 BAR

Spring Range : N/A

Back Pressure: 0.0 BAR

Size Inlet / Outlet : 3/4" X 1"

CDTP : 16.0 BAR

Setting Accuracy : ± 3 % of Setting

Type of Valve : Metal Seated

Pop Test : PASSED

Test Medium : Air/Water/Oil/Gas

BASIS OF TEST:

Ref Standard ASME Sec VIII, Div I

Summary of Test Procedure:

The Calibration of above Pressure relief valve is performed through the verification of set pressure and seat tightness using a reference standard pressure gauge or test gauge and a hydrostatic / pneumatic test system.

Traceability:

The reported tests were undertaken using equipment detailed mentioned in Reference Standard Equipment's for which the company Maintains traceability to the third party.

Condition of Instrument

With in the tolerance on receipt(as found)

No

The instrument was adjusted

Yes

The instrument was repaired

No

++++ End of the Certificate +++++

Calibrated By:

Calibration Engineer

UIC QP-7.8.2-17,REV 02

Approved by:

QA/QC Engineer