شركة مساندة الإعمار للفحص
Emaar Support Inspection Co.
6888, King Faisal Bin Abdul Aziz St, Ad Danah, Ras Tannurah, Saudi Arabia 32817
Tel : +966 507259023, +966 136670779, 055 8889186, 050 0484444
Email : info@esico.com.sa Website : www.esico.com.sa C.R : 2054100036

CERTIFICATE OF THOROUGH EXAMINATION OF DIESEL GENERATOR MACHINE

Date of thorough examination : **14-10-2026**	Date of issue : **14-10-2026**	Report No. : **ESICO-LFT-R26-11474**

Name & Address of employer	Location	Sticker	Standards
GLOBAL GALLANTRY GENERAL CONTRACTING EST.	P3 SEVEN DAMMAM	13126	SASO ISO 12100

Equipment Identification No	Equipment Description	Safe Working Load(s)	Date of Manufacture	Manufacturer Name
SG-972-500 OR VEPL/2023-24/520	DIESEL GENERATOR MODEL: VEPL-500-CDP VOLTAGE: 220V CLASS: H/H RATED POWER FACTOR: 0.8 FREQUENCY: 60Hz PHASE: 3 RPM: 1800	500KVA	2024	VARADA

Is this the first examination after installaton or assembly at a new site or location?	Yes	-	No	✗	
If the answer to the above question is YES, has the equipment been installed correctly?	Yes	-	No	-	
Was the examination carried out within an interval of?	- 6 Months				
In accordance with an examination scheme?	Yes	✓	No	-	
After the occurence of exceptional circumstances?	Yes	-	No	✗	

Identification of any part found to have a defect which is or could become a danger to persons and a description of the defect (if none state NONE) : NONE	
Is the above an existing or imminent danger to persons, Note: This is a reportable defect?	No
Is the above a defect which is not yet could become a danger to persons (if YES state the date by when)	Yes by : N/A
Particulars of any repair, renewal or alteration required to remedy the defect identified above : NONE	
Particulars of any tests carried out as part of the examination (if none state NONE) : VISAUL AND FUNCTIONAL TEST	
Observation/additional comments relative to this thorough examination : CLEAN THE INSIDE COMPARTMENT	

For confirmation scan QR code
search with report number : **ESICO-LFT-R26-11474**

✓ Safe to operate

Next Inspection : 13-04-2027

Inspected by : Eric Kwesi Ankomanyi