



الشركة العالمية لخدمات التفتيش المحدودة UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س. ت ٢٠٥٥٠١١٦٤٣

THOROUGH EXAMINATION CERTIFICATE OF DIESEL GENERATOR

Report No:	DUB-INS-2025-06-00222	Report Issue Date:	21-Jun-2025
Customer Name:	SUDHIR EQUIPMENT RENTAL COMPANY	Inspection Type:	Visual Inspection
Address:	Duba, Kingdom of Saudi Arabia	Serial Number	1602B3309
Site Location:	SHIGRY-KSA	Equipment Id Number:	SG-067-60
Standard Reference:	ISO 8528-5:2022	Manufacturer:	CUMMINS
Inspection Date:	21-Jun-2025	Equipment Model/Type:	CS62.5D5P
Next Inspection Date:	20-Dec-2025	Sticker No:	DUB/000145

Description	Capacity/SWL	Reason For Examination	Result	Safe To Use
Rated Power	60 KVA	B	Satisfactory	YES
Rated Voltage	415 V			
Rated Frequency	50 Hz			
Rated Speed	1500 rpm			
Phase	3 Ph			
Power Factor	0.8			
M.f.g Year	Feb-2016			
Internal Visual Test	Satisfactory			
General Surface Test	Satisfactory			
Compressor Shut-Down	Satisfactory.			

Reason For Exam.	A 3 Months	B 6 Months	C 12 Months	D Written Scheme	E Exceptional Circumstance	F Installation
------------------	---------------	---------------	----------------	---------------------	-------------------------------	-------------------

Result	ACCEPTED	REJECTED (See Attached Defect Report)
--------	----------	--

Declaration:

I hereby declare that the above information is correct and that the equipment has been thoroughly examined as far as possible in accordance with the appropriate provisions/Standards that at the time of the Inspection/examination and found to be free from any defect likely to affect safety other than theses detailed above.

Inspected By:		Approved By:	
Stamp By:		REMON RAJ	
		Designation:	
		Inspection Supervisor	

No liability will be considered against UNIVERSAL INSPECTION COMPANY for failure, damage or other occurrence to Client owned or operated equipment due to misuse, improper installations, poor maintenance, weather/environmental conditions & equipment operator/user mistakes or uncontrolled operation & maintenance. This Inspection Certificate/Report shall not be reproduced except in full without the approval UIC and the Client.

 أرامكو السعودية saudi aramco	 The Red Sea Development Company	 سابك SABIC	 الشركة السعودية للكهرباء Saudi Electricity Company	 معادن شركة التعدين العربية السعودية MA'ADEN
VENDOR ID: 10044577	APPROVED VENDOR	VENDOR ID: 11052442	VENDOR ID: 5014041	VENDOR ID: 10857

P.O Box no. 2072, Jubail-31951, KSA
Tel.: +966 13 344 8882 / Fax.: +966 13 344 8881
Tel.: +966 13 367 0515
Website: www.ui.com.sa



For Verification of This Report Scan Above QR Code:

The PDF document is electronically generated and digitally signed

Doc No. UIC FMT 091-E/Rev No.-00

ص.ب 2072 ، الجبيل 31951 - المملكة العربية السعودية
+ هاتف: 966 13 344 8882 / فاكس: 966 13 344 8881
+ هاتف: 966 13 367 0515
الموقع الإلكتروني: www.ui.com.sa



الشركة العالمية لخدمات التفتيش المحدودة UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س. ت ٢٠٥٥٠١١٦٤٣

THOROUGH EXAMINATION CERTIFICATE OF DIESEL GENERATOR

Report No:	DUB-INS-2025-06-00223	Report Issue Date:	21-Jun-2025
Customer Name:	SUDHIR EQUIPMENT RENTAL COMPANY	Inspection Type:	Visual Inspection
Address:	Duba, Kingdom of Saudi Arabia	Serial Number	2017SVEPL003
Site Location:	SHIGRY-KSA	Equipment Id Number:	SG-117-60
Standard Reference:	ISO 8528-5:2022	Manufacturer:	N/A
Inspection Date:	21-Jun-2025	Equipment Model/Type:	AL4DTG3
Next Inspection Date:	20-Dec-2025	Sticker No:	DUB/000146

Description	Capacity/SWL	Reason For Examination	Result	Safe To Use
Rated Voltage Rated Frequency Rated Speed Phase Rated Power Power Factor M.f.g Year Internal Visual Test General Surface Test Compressor Shut-Down	415 V 60 Hz 1800 rpm 3 Ph 60 KVA 0.8 2017 Satisfactory Satisfactory Satisfactory.	60 KVA B	Satisfactory	YES


Reason For Exam.	A 3 Months	B 6 Months	C 12 Months	D Written Scheme	E Exceptional Circumstance	F Installation
Result	ACCEPTED			REJECTED (See Attached Defect Report)		

Declaration:

I hereby declare that the above information is correct and that the equipment has been thoroughly examined as far as possible in accordance with the appropriate provisions/Standards that at the time of the Inspection/examination and found to be free from any defect likely to affect safety other than those detailed above.

Inspected By:		Approved By: REMON RAJ	
Stamp By:		Designation: Inspection Supervisor	

No liability will be considered against UNIVERSAL INSPECTION COMPANY for failure, damage or other occurrence to Client owned or operated equipment due to misuse, improper installations, poor maintenance, weather/environmental conditions & equipment operator/user mistakes or uncontrolled operation & maintenance. This Inspection Certificate/Report shall not be reproduced except in full without the approval UIC and the Client.



VENDOR ID: 10044577



APPROVED VENDOR



VENDOR ID: 11052442



VENDOR ID: 5014041



VENDOR ID: 10857

P.O Box no. 2072, Jubail-31951, KSA
Tel.: +966 13 344 8882 / Fax.: +966 13 344 8881
Tel.: +966 13 367 0515
Website: www.ui.com.sa



For Verification of This Report Scan Above QR Code:

The PDF document is electronically generated and digitally signed

ص.ب 2072 ، الجبيل 31951 - المملكة العربية السعودية
+966 13 344 8882 / فاكس: +966 13 344 8881
+966 13 367 0515 هاتف:
الموقع الإلكتروني: www.ui.com.sa

Doc No. UIC FMT 091-E/Rev No.-00