

CERTIFICATE OF THOROUGH EXAMINATION

DIESEL GENERATOR

CERTIFICATE / REPORT NO : CRT-205466 R.0

STICKER NO : 155395

JOB NO : WO-54579

DATE OF REPORT : 12/05/2026 4:32:31 AM

EQUIPMENT OWNER : SUDHIR RENTALS		TYPE OF INSPECTION : INITIAL INSPECTION	
LOCATION: BISHA	DATE OF INSPECTION : 26-Apr-2026	Frequency 6 month	Next Inspection Due 25-Oct-2026
EQUIPMENT DESCRIPTION : DIESEL ENGINE POWERED GENERATOR OF RATED CAPACITY 60 KVA			
MANUFACTURER : VARADA ENERGIES	MODEL/TYPE : VEPL-60-CDP	MANUFACTURED YEAR : 2023	
SERIAL NO : VEPL/2022-23/211	OWNER ID : SG-787-60	WORK PROCEDURE NO : SA-WP-06	
REFERENCE STANDARDS : ISO 8528-13:2016	DATE OF PREVIOUS INSPECTION :	PREVIOUS INSPECTION DETAILS: NA	
CAPACITY = 60 KVA		RATED POWER = 48 KW	
VOLTAGE / FREQUENCY = (400/230 V) / 50 HZ		RATED CURRENT = 86 A	
PHASE= 3 PHASE		RATED SPEED = 1500 RPM	
RESULT : SATISFACTORY-PASS		CHECKLIST NO : 96649	
REMARKS/RECOMMENDATION : 1. FOLLOW THE PREVENTIVE MAINTENANCE PROCEDURES AS PER MANUFACTURER INSTRUCTIONS TO KEEP THE EQUIPMENT ALWAYS IN GOOD CONDITION. 2. DO PRE-OPERATIONAL INSPECTION TO ENSURE THE EQUIPMENT IS FREE FROM ANY KIND OF LEAKAGES OR LOOSE CONNECTIONS			

Reviewed By : ARIF AL-RASHIDI

Authorised Inspector : ZEIN UL ABEDIN KILLEDAR

Phil



Train

Note : This inspection certificate confirms that the inspected equipment comply with the specified requirements as per the inspection criteria. However, this document does not constitute a conformity certificate for SABER.

ملحوظة: تؤكد شهادة الفحص هذه أن المعدات التي تم فحصها تتوافق مع المتطلبات المحددة وفقًا لمعايير الفحص. مع ذلك، هذه الوثيقة لا تعتبر شهادة مطابقة لمنصة سابر.

THIS CERTIFICATE BECOMES INVALID, IF ANY ALTERATION/REPAIR OR MODIFICATION IS MADE TO THE EQUIPMENT

THE CONCERNED INSPECTOR OR REPRESENTATIVE HAS THOROUGHLY EXAMINED THE EQUIPMENT IN ACCORDANCE TO THE RELEVANT STANDARDS. EXAMINATION INDICATES THAT THE SAID EQUIPMENT HAS NO APPARENT DEFECTS OR DEFORMATION WHICH MAY PROVE DANGEROUS DURING NORMAL OPERATION. THE SAID EQUIPMENT IS FOUND TO BE SATISFACTORY FOR FURTHER USE. IT IS RECOMMENDED THERE IS REGULAR MAINTENANCE AND OPERATED BY CERTIFIED OPERATOR. THIS CERTIFICATE IS GRANTED SUBJECT TO THE FOLLOWING CONDITIONS: IT IS THEED UNDERSTOOD THAT THE STANDARD ARABIA INSPECTION CO. LTD. SHALL BE IN NO WAY BE LIABLE IN CASE OF ITS EMPLOYEES OR PREMISES OF SUBCONTRACTORS UNDER NO CIRCUMSTANCES WHATSOEVER SHALL STANDARD ARABIA INSPECTION CO. LTD. BE LIABLE FOR ANY INJURY OR DAMAGE TO ANY PERSON OR OCCURRING AS A RESULT OF NEGLIGENT OPERATION OR ANY DEFECT IN MATERIALS, MACHINERY, EQUIPMENT OR SYSTEMS OTHER THAN DEFECTS ASCERTAINABLE DURING ROUTINE INSPECTION. WE HEREBY REPORT THAT THE ALL PARTICULARS IN THIS REPORT ARE CORRECT AT THE TIME OF TEST / INSPECTION & OPERATIONAL MAINTENANCE IS THE SOLE RESPONSIBILITY OF THE EQUIPMENT OWNER.

THIS CERTIFICATE IS GENERATED AND AUTHORIZED ELECTRONICALLY AND CAN BE CONSIDERED AS ORIGINAL. TO VERIFY THE AUTHENTICITY OF THIS CERTIFICATE, PLEASE SCAN THE QR CODE.