

CERTIFICATE OF CONFIRMATION (COC)**Product:** Socket Panel**Reference No.:** COC/2025/01934

This is to certify that the **Socket Panel test** conducted on **29-Dec-2025** has been successfully completed for the following panel:

Asset ID	Capacity
SSP-250-051	250 MAIN BREAKER Socket Panel (160A x 1-4P; 63A x 2-4P RCCB; 40A x 4-4P RCCB; 25A x 6-2P RCCB Breakers)

The entire testing process was meticulously executed by our dedicated team of experts, ensuring that all necessary precautions were taken to guarantee accurate results. State-of-the-art equipment was employed, and industry best practices were followed to conduct a comprehensive evaluation of the socket panel's integrity.

The socket panel was subjected to **electrical insulation, continuity, earthing, polarity, and functional testing**. All tests were completed successfully, and no defects or safety non-conformities were identified.

This certification confirms that the socket panel meets the required safety and operational standards.

On behalf of
Sudhir Equipment Rental Company

