

OWNERSHIP CERTIFICATE

To Whom It May Concern

This is to certify that the following equipment listed below is the sole property of Sudhir Equipment Rental Company:

Equipment	Generator
Brand / Make	VARADA
Asset ID	SG-992-500
Model Number	VEPL-500-CDP
Serial Number	VEPL/2024-25/42
Engine Number	6M21G460/6
Alternate Serial Number	N24B095529
Manufacturing Year	2024

This certification is issued to confirm the ownership status of the aforementioned equipment. Sudhir Equipment Rental Company holds full legal ownership rights over the listed equipment and retains all associated benefits and responsibilities. Should there be any queries or requests for verification regarding the ownership of the mentioned equipment, please do not hesitate to contact us at : Info@sudhirrentals.com

Sincerely,

Ajay Koul

General Manager

Sudhir Equipment Rental Company





Certificate of Insurance

Policy Holder Name
Policy Number
Original Policy Period

Sudhir Equipment Rental Company
5/EP/30425/0/0
05/04/2026 to 04/04/2027

اسم حامل الوثيقة
رقم الوثيقة
فترة الوثيقة الأصلية

Gulf Insurance Group certifies that above client is holding Contractor's Plant & Machinery Insurance Policy for the below mentioned Equipment in accordance with the above mentioned Insurance Policy:

تشهد مجموعة الخليج للتأمين بأن العميل المذكور أعلاه يحمل وثيقة تأمين على معدات والآلات المقاولين للمعدة المذكورة أدناه، وذلك وفقاً لشروط وثيقة التأمين المذكورة أعلاه:

Asset ID	:	SG-992-500	:	معرف الأصل
Brand	:	VARADA	:	العلامة التجارية
Type	:	VEPL-500-CDP	:	النوع
Model	:	Diesel Generator	:	الطراز
Manufacturing Year	:	2024	:	سنة الصنع
Equipment Serial Number	:	VEPL/2024-25/42	:	الرقم التسلسلي للمعدة
Insurance Effective Date	:	05/04/2026	:	تاريخ سريان التأمين

This Certificate has been issued upon Insureds request as per all terms and conditions, exclusions, warranties mentioned in the policy.

تم إصدار هذه الشهادة بناء على طلب المؤمن له وذلك حسب الشروط والاستثناءات والاشتراطات المذكورة في الوثيقة

Al Khobar : 01st April 2026

Signature of Insurer's Authorized Representative



PUBLIC

Gulf Insurance Group

A Saudi joint stock company | Paid-up capital 500 Million Saudi Riyals
Licensed by No (TMN/25/20101) | Commercial Registration No.1010271203
3528 King Abdullah Bin Abdulaziz Road, Al Nuzha District
Unit No. 25 | Riyadh 12471 - 6378
Toll free 8001160020 | Website www.gig.sa
Regulated and Supervised by The Saudi Central Bank

مجموعة الخليج للتأمين

شركة مساهمة سعودية | رأس المال 500,000,000 ريال سعودي
مرخص لها برقم ترخيص (ت م ن/25/20101) | سجل تجاري رقم 1010271203
3528 طريق الملك عبد الله بن عبدالعزيز، حي النزهة
رقم الوحدة 25 | الرياض 12471 - 6378
www.gig.sa الرقم المجاني 8001160020 | الموقع الإلكتروني
خاضعة لرقابة وإشراف البنك المركزي السعودي



REPORT OF INSPECTION

Cert. No.: 2202709	Date of Examination: 11/06/2025	Sticker No.: 01-90226
Equipment Owner	Sudhir Equipment Rental Company	
Place of Inspection	Dammam Yard	
Equipment Type	Portable Diesel Generator.	
Manufacturer Name	VARADA/BAUDOUIN	
Owner ID	SG-992-500	
Serial No.	VEPL/2024-25/42	
Model	VEPL-500-CDP	
Rated Power	500 KVA	
Voltage / Frequency	4000 V / 60 HZ / 400 KW	
Speed	-	

At the request of Sudhir Equipment Rental Company, Surveyor to BUREAU VERITAS, acting within the General Conditions of Services of the Society, attended on 11/06/2025 at Dammam Yard to witness Test and/or to carry out Thorough Examination of the above-mentioned equipment as per ISO 8528.

Inspection Activities:

Prior to commencing performance test, visual inspection of the equipment was carried out and no visible defects were observed. The equipment was then operated to all the functions to verify the performance of the equipment.

Result of Inspection:

Based on the visual inspection of the Portable Diesel Generator. and upon post-performance test & thorough examination, the above mentioned equipment has been found free from damage and/or permanent deformation at the time of inspection & is considered to be safe for further use, subject to continuous maintenance being applied and qualified operator being employed.

Remarks:

- Maintain regular maintenance.
- Maintain regular housekeeping

Next Inspection Due on or before: 10/12/2025

Issued at Al Khobar on 08/04/2026

Inspected by

Signature:



Name: Mohamed Elsbary
Position: Inspector



Reviewed by
Signature:



Name: Ahmed Elabady
Position: Reviewer

The technical conclusions thus expressed may have to be reconsidered in light of any modifications or alterations that would invalidate the data shown in the present certificate. These conclusions would become null & void should Bureau Veritas not be kept informed of such modifications or alterations with specific reference to the present certificate.

Any person not a party to the contract pursuant to which this document is delivered may not assert a claim against Bureau Veritas for any liability arising out of errors or omissions which may be contained in said document, or for errors of judgement, fault or negligence committed by the personnel of the Society or of its Agents in the establishment or issuance of this document, and in connection with any activities for which it may provide.


This not is NOT an indication that the item(s) is (are) fit for any specific purpose and does not release the manufacture, supplier and any party from their respective duty, guarantee, obligation and/or indemnity relating to, without limitation patents, workmanship, materials, safety, performance in operation and/or reliability.



CHECKLIST OF TEST & THOROUGH EXAMINATION

Inspection Sticker No.:01-90226		Date of Examination: 11/06/2025
DESCRIPTION		CONDITION/REMARKS
1.	Physical condition of the equipment	Satisfactory
2.	Condition of the display panel / gauges	Satisfactory
3.	Visibility & functionality of the emergency stop button	Satisfactory
4.	Condition of the generator door	Satisfactory
5.	Condition of the power supply panel	Satisfactory
6.	Condition of the diesel tank	Satisfactory
7.	Indication of any leakage observed	Satisfactory
8.	Any unnecessary vibration observed	Satisfactory
9.	Placement / Environment of the generator	Satisfactory
10.	Ventilation condition	Satisfactory
11.	Availability of suitable fire extinguisher and/or sand	Satisfactory
12.	Insulation rubber mat at all panels / gauges	Satisfactory
13.	Markings / Labels & warning signage	Satisfactory
14.	Spill observant kit or drip tray	Satisfactory
15.	Electrical grounding condition	Satisfactory
16.	Condition of the skid	Satisfactory
17.	Name plate	Satisfactory
Remarks: -		

Inspector to Bureau Veritas
Signature:




Name: Mohamed Elsabry
Position: Inspector

The technical conclusions thus expressed may have to be reconsidered in light of any modifications or alterations that would invalidate the data shown in the present certificate. These conclusions would become null & void should Bureau Veritas not be kept informed of such modifications or alterations with specific reference to the present certificate.

Any person not a party to the contract pursuant to which this document is delivered may not assert a claim against Bureau Veritas for any liability arising out of errors or omissions which may be contained in said document, or for errors of judgement, fault or negligence committed by the personnel of the Society or of its Agents in the establishment or issuance of this document, and in connection with any activities for which it may provide.

This not is NOT an indication that the item(s) is (are) fit for any specific purpose and does not release the manufacture, supplier and any party from their respective duty, guarantee, obligation and/or indemnity relating to, without limitation patents, workmanship, materials, safety, performance in operation and/or reliability.



No. LFT-S.

01 - 90226



BUREAU
VERITAS
Saudi Arabia

Tel: +966 13 882 1071

Fax: +966 13 882 1072



EQUIP. NO. SG-992-500

EQUIP. S N. VEPL/2024-25/42

S. W. L: N/A

DATE OF INSPECTION 08-APR-2026

NEXT INSPECTION DUE ON 07-OCT-2026

INSPECTED BY Mohammed Lundy

This sticker is issued under Bureau veritas General
Conditions of Service and is valid only in conjunction
with hereafter inspection Report No.
Report No. LFT-R