THOROUGH EXAMINATION CERTIFICATE OF GENERATOR

Report No:	TUR-INS-2026-08-04644	**Report Issue Date:**	11-Aug-2026
Customer Name:	Sudhir Equipment Rental Company	**Inspection Type:**	Functional & Visual Check
Address:	Al-Turaif Kingdom of Saudi Arabia	**Serial Number**	VEPL/2022-23/238
Site Location:	Was,Al-Turaif	**Equipment Id Number:**	SG-802-500
Standard Reference:	ISO 8528-5:2022	**Manufacturer:**	VARADA ENERGIES
Inspection Date:	10-Aug-2026	**Equipment Model/Type:**	N/A
Next Inspection Date:	09-Feb-2027	**Sticker No:**	TUR/005197

Description		Capacity/SWL	Reason For Examination	Result	Safe To Use
Rated Power(KVA)	500 KVA	500 KVA	B	Satisfactory	YES
Rated Power(KW)	400 KW				
Rated Voltage	400 V				
Frequency	Hz				
Phase	3				
Power Factor	0.8Φ				
Electrical & Battery	Satisfactory				
Control Panel & Grounding	Satisfactory				
Emergency stop button	Satisfactory				
Internal Visual Test	Satisfactory				
General Surface Test	Satisfactory				

Reason For Exam.	A 3 Months	B 6 Months	C 12 Months	D Written Scheme	E Exceptional Circumstance	F Installation

Result	ACCEPTED	REJECTED (See Attached Defect Report)

Declaration:

I hereby declare that the above information is correct and that the equipment has been thoroughly examined as far as possible in accordance with the appropriate provisions/Standards that at the time of the Inspection/examination and found to be free from any defect likely to affect safety other than theses detailed above.

Inspected By:	UIC 100 INSPECTOR	**Approved By:** MOHAMED NOORUL AMEEN	**Signature:**
Stamp By:		**Designation:** Inspection Supervisor	

No liability will be considered against **UNIVERSAL INSPECTION COMPANY** for failure, damage or other occurrence to Client owned or operated equipment due to misuse, improper installations, poor maintenance, weather/environmental conditions & equipment operator/user mistakes or uncontrolled operation & maintenance. This Inspection Certificate/Report shall not be reproduced except in full without the approval UIC and the Client.