

THOROUGH EXAMINATION CERTIFICATE OF GENERATOR

Report No:	UIC-INS-2026-09-64634	Report Issue Date:	21-Sep-2026
Customer Name:	Sudhir Equipment Rental Company	Inspection Type:	Functional & Visual Check
Address:	AL-Jubail, Kingdom of Saudi Arabia	Serial Number	VEPL/2024-25/248
Site Location:	FGIP-PKG-2	Equipment Id Number:	SG-1130-500
Standard Reference:	ISO 8528-5:2022	Manufacturer:	VARADA
Inspection Date:	21-Sep-2026	Equipment Model/Type:	VEPL-500-CDP
Next Inspection Date:	20-Mar-2027	Sticker No:	UIC/223076

Description	Capacity/SWL	Reason For Examination	Result	Safe To Use
Rated Prime Power	500KVA	B	Satisfactory	YES
Frequency	60 Hz			
Rated Voltage	400V			
Amps Base Rating (BR)	55.6A			
Rated Speed	1800RPM			
Motive Power	Diesel			
Rated Power Factor	0.8			
Internal Visual Test	Satisfactory			
General Surface Test	Satisfactory			
Functional Check	Satisfactory			

Reason For Exam.	A 3 Months	B 6 Months	C 12 Months	D Written Scheme	E Exceptional Circumstance	F Installation
Result	ACCEPTED			REJECTED (See Attached Defect Report)		

Declaration:

I hereby declare that the above information is correct and that the equipment has been thoroughly examined as far as possible in accordance with the appropriate provisions/Standards that at the time of the Inspection/examination and found to be free from any defect likely to affect safety other than theses detailed above.

Inspected By:		Approved By:	Signature:
Stamp By:		MOHAMMED MUSTAQ	
		Designation:	
		Inspection Supervisor	

No liability will be considered against UNIVERSAL INSPECTION COMPANY for failure, damage or other occurrence to Client owned or operated equipment due to misuse, improper installations, poor maintenance, weather/environmental conditions & equipment operator/user mistakes or uncontrolled operation & maintenance. This Inspection Certificate/Report shall not be reproduced except in full without the approval UIC and the Client.

