

OWNERSHIP CERTIFICATE

To Whom It May Concern

This is to certify that the following equipment listed below is the sole property of Sudhir Equipment Rental Company:

Equipment	CHILLERS
Brand / Make	MIDEA
Asset ID	SPU25-076
Model Number	MRCT-250CWN1-Y(D)
Serial Number	25 TR PU
Manufacturing Year	2025

This certification is issued to confirm the ownership status of the aforementioned equipment. Sudhir Equipment Rental Company holds full legal ownership rights over the listed equipment and retains all associated benefits and responsibilities. Should there be any queries or requests for verification regarding the ownership of the mentioned equipment, please do not hesitate to contact us at :

Info@sudhirrentals.com

Sincerely,

Rajesh Thakur
Plant Manager

Sudhir Equipment Rental Company





Certificate of Insurance

Policy Holder Name
Policy Number
Original Policy Period

Sudhir Equipment Rental Company
5/EP/30425/0/0
05/04/2026 to 04/04/2027

اسم حامل الوثيقة
رقم الوثيقة
فترة الوثيقة الأصلية

Gulf Insurance Group certifies that above client is holding Contractor's Plant & Machinery Insurance Policy for the below mentioned Equipment in accordance with the above mentioned Insurance Policy:

تشهد مجموعة الخليج للتأمين بأن العميل المذكور أعلاه يحمل وثيقة تأمين على معدات والآلات المقاولين للمعدة المذكورة أدناه، وذلك وفقاً لشروط وثيقة التأمين المذكورة أعلاه:

Asset ID	:	SPU25-076	:	معرف الأصل
Brand	:	MIDEA	:	العلامة التجارية
Type	:	MRCT-250CWN1-Y(D)	:	النوع
Model	:	Chillers	:	الطراز
Manufacturing Year	:		:	سنة الصنع
Equipment Serial Number	:		:	الرقم التسلسلي للمعدة
Insurance Effective Date	:	05/04/2026	:	تاريخ سريان التأمين

This Certificate has been issued upon Insureds request as per all terms and conditions, exclusions, warranties mentioned in the policy.

تم اصدار هذه الشهادة بناء على طلب المؤمن له وذلك حسب الشروط والاستثناءات والاشتراطات المذكورة في الوثيقة

Al Khobar : 01st April 2026

Signature of Insurer's Authorized Representative



PUBLIC

Gulf Insurance Group

A Saudi joint stock company | Paid-up capital 500 Million Saudi Riyals
Licensed by No (TMN/25/20101) | Commercial Registration No.1010271203
3528 King Abdullah Bin Abdulaziz Road, Al Nuzha District
Unit No. 25 | Riyadh 12471 - 6378
Toll free 8001160020 | Website www.gig.sa
Regulated and Supervised by The Saudi Central Bank

مجموعة الخليج للتأمين

شركة مساهمة سعودية | رأس المال 500,000,000 ريال سعودي
مرخص لها برقم ترخيص (ت م ن/25/20101) | سجل تجاري رقم 1010271203
3528 طريق الملك عبدالله بن عبدالعزيز، حي النزهة
رقم الوحدة 25 | الرياض 12471 - 6378
www.gig.sa الرقم المجاني 8001160020 | الموقع الإلكتروني
خاضعة لرقابة وإشراف البنك المركزي السعودي



الشركة العالمية لخدمات التفتيش المحدودة UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت ٢٠٥٥٠١١٦٤٣

THOROUGH EXAMINATION CERTIFICATE OF AC CHILLER

Report No:	DAM-INS-2026-05-19387	Report Issue Date:	31-May-2026
Customer Name:	Sudhir Equipment Rental Co.	Inspection Type:	Functional & Visual Check
Address:	Dammam	Serial Number	540X4821001AB040100002
Site Location:	DAMMAM YARD	Equipment Id Number:	SPU25-076
Standard Reference:	N/A	Manufacturer:	MIDEA
Inspection Date:	31-May-2026	Equipment Model/Type:	MRCT-250CWN1-Y(D)
Next Inspection Date:	30-Nov-2026	Sticker No:	DAM/013823

Description		Capacity/SWL	Reason For Examination	Result	Safe To Use
Voltage Range	380-415 V	Cooling Capacity :282000 Btu/h	B	Satisfactory	YES
Frequency / No.of Phase	60 Hz/ 3				
Internal Visual Test	Satisfactory				
Functional Check	Satisfactory				
General Condition	Satisfactory				
Rated Power	82.6 kW				


Reason For Exam.	A 3 Months	B 6 Months	C 12 Months	D Written Scheme	E Exceptional Circumstance	F Installation
Result	ACCEPTED			REJECTED (See Attached Defect Report)		

Declaration:

I hereby declare that the above information is correct and that the equipment has been thoroughly examined as far as possible in accordance with the appropriate provisions/Standards that at the time of the Inspection/examination and found to be free from any defect likely to affect safety other than those detailed above.

Inspected By:		Approved By:	 Signature: MOHAMED WASIM IBRAHIM
Stamp By:		Designation: Inspection Supervisor	

No liability will be considered against UNIVERSAL INSPECTION COMPANY for failure, damage or other occurrence to Client owned or operated equipment due to misuse, improper installations, poor maintenance, weather/environmental conditions & equipment operator/user mistakes or uncontrolled operation & maintenance. This Inspection Certificate/Report shall not be reproduced except in full without the approval UIC and the Client.



VENDOR ID: 1004457



APPROVED VENDOR



VENDOR ID: 11052442



VENDOR ID: 5014041



VENDOR ID: 10857

P.O Box no. 2072, Jubail-31951, KSA
Tel.: +966 13 344 8882/Fax.: +966 13 344 8881
Tel.: +966 13 367 0515
Website: www.ui.com.sa



For Verification of This Report Scan Above QR Code:

The PDF document is electronically generated and digitally signed

ص.ب 2072 ، الجبيل 31951 - المملكة العربية السعودية
+هاتف: 966 13 344 8882 / فاكس: 966 13 344 8881
+هاتف: 966 13 367 0515
الموقع الإلكتروني: www.ui.com.sa

Doc No. UIC FMT 091-E/Rev No.-00



الشركة العالمية لخدمات التفتيش المحدودة
UNIVERSAL INSPECTION CO. LTD.

INSPECTION DIVISION
EQUIPMENT INSPECTION

NO. DAM/013823

TYPE OF EQUIPMENT : AC Chiller Unit
EQUIPMENT ID NO : SPV25-076
SERIAL NUMBER : 540X4821001AB040100002
DATE OF INSPECTION : 31-may-2026
DATE OF EXPIRY : 30-Nov-2026
INSPECTED BY : UIC-21

Contact No. Tel.: +966 13 344 8882, Fax: +966 13 344 8881
Website : www.ui.com.sa
UIC FMT 091-E-ST / Rev No - 00

MODEL NO.: MRCT-250CWN1-Y(D)

COOLING: 282 000 Btu/h(82.6 kW) POWER: 28 200 W EER: 10.0 Btu/(W·h) CURRENT: 56.2 A (T1)
COOLING: 248 000 Btu/h(72.7 kW) POWER: 34 100 W EER: 7.3 Btu/(W·h) CURRENT: 63.5 A (T3)

ELECTRICAL DATA

ELECTRICAL RATING
CONTROL CIRCUIT VOLTS

380-415 V 3N- 60 Hz