الشركة العالمية لخدمات التفتيش المحدودة
UNIVERSAL INSPECTION CO. LTD.
CR No. 2055011643
س. ت ٢٠٥٥٠١١٦٤٣

THOROUGH EXAMINATION CERTIFICATE OF GENERATOR

Report No:	SAF-INS-2026-10-10064	**Report Issue Date:**	14-Oct-2026
Customer Name:	Sudhir Equipment Rental Company	**Inspection Type:**	Visual Inspection
Address:	Dammam, Kingdom Of Saudi Arabia.	**Serial Number**	VEPL-2017/18-0113
Site Location:	Zuluf	**Equipment Id Number:**	SG-226-60
Standard Reference:	ISO 8528-5:2022	**Manufacturer:**	STAMFORD/2017
Inspection Date:	13-Oct-2026	**Equipment Model/Type:**	VEPL-62.5-CDP
Next Inspection Date:	12-Apr-2027	**Sticker No:**	SAF/008195

Description		Capacity/SWL	Reason For Examination	Result	Safe To Use
Rated Power	60 KVA	60 KVA	B	Satisfactory	YES
Rated Voltage	230V				
Rated Speed	1800 RPM				
Phase& Power Factor	3 & 0.8Φ				
Fluid Levels & Systems	Satisfactory				
Electrical & Battery	Satisfactory				
Control Panel & Grounding	Satisfactory				
Mechanical & Physical Condition	Satisfactory				
Emergency stop button	Satisfactory				
Fire extinguisher	Satisfactory				
Internal Visual Test	Satisfactory				
General Surface Test	Satisfactory				

Reason For Exam.	A	B	C	D	E	F
	3 Months	6 Months	12 Months	Written Scheme	Exceptional Circumstance	Installation

Result	ACCEPTED	REJECTED (See Attached Defect Report)

Declaration:

I hereby declare that the above information is correct and that the equipment has been thoroughly examined as far as possible in accordance with the appropriate provisions/Standards that at the time of the Inspection/examination and found to be free from any defect, WHICH may affect other than theses detailed above.

Inspected By:	UIC 61 INSPECTOR	Approved By: BALAJI KRISHNAMOORTHY	Signature:
Stamp By:		Designation: Inspection Supervisor	

No liability will be considered against **UNIVERSAL INSPECTION COMPANY** for failure, damage or other occurrence to Client owned or operated equipment due to misuse, improper installations, poor maintenance, weather/environmental conditions & equipment operator/user mistakes or uncontrolled operation & maintenance. This Inspection Certificate/Report shall not be reproduced except in full without the approval **UIC** and the Client.

VENDOR ID: 1004457 | APPROVED VENDOR | VENDOR ID : 11052442 | VENDOR ID: 5014041 | VENDOR ID: 10857

P.O Box no. 2072, Jubail-31951, KSA
Tel.: +966 13 344 8882/Fax.: +966 13 344 8881
Tel.: +966 13 367 0515
Website: www.ui.com.sa

ص.ب 2072 ، الجبيل 31951 - المملكة العربية السعودية
+هاتف: 8882 344 13 966+ / فاكس: 8881 344 13 966
+هاتف: 0515 367 13 966
الموقع الالكتروني www.ui.com.sa

For Verification of This Report Scan Above QR Code.

The PDF document is electronically generated and digitally signed

الشركة العالمية لخدمات التفتيش المحدودة
UNIVERSAL INSPECTION CO. LTD.

Work Completion Report For On Site Calibration & Inspection

No. 53417

Company Name & Address of the Site Location:

Company / Customer Name : Sudhir

Mr. /Mrs: _____

Mobile/Tel. No.: _____

Email ID : _____

Purchase Order No. : _____

Date Of ~~Calibration~~ / Inspection : 13 - 10 - 26

~~Calibration~~ / Inspection Validity : 12 6M / 1Y 2027

Location : Zulup

UIC Cert. No. /Sticker No.	Description			Calibration Status/ (Sticker Issued)		Final ~~Results/Remarks~~
	Name/Description	Make/Model	SL.No. /ID.No.	Yes	No	Ok / NO
008195	Generator		VEPL-2017/18-0113	☑	☐	SG-226-60
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	
				☐	☐	

UNIVERSAL INSPECTION CO. LTD. C.R. 2055011643

Cal. Engr/Insp. Sign: _____ Name: S. Ahamed

(Client Sign) Azhar Name: _____ Contact No: 059 827 4794 Site Location: Zulup

Witnessed & Approved by