



الشركة العالمية لخدمات التفتيش المحدودة  
**UNIVERSAL INSPECTION CO. LTD.**

CR No.2055011643

س.ت ٢٠٥٥٠١١٦٤٣



## **CERTIFICATE OF INSPECTION**

**Certificate No: UIC/DAM/20242623**

**Customer :** Sudhir Equipment Rental Company  
**Location :** Abquiq, Kingdom of Saudi Arabia.  
**Description :** Generator  
**Make :** Varada Energies Pvt.Ltd.  
**Model :** N/A  
**Serial Number :** VEPL/2023-24/241  
**ID Number :** SG-866-125  
**Capacity :** 125.0 KVA

This is to certify that the description detailed hereby has been inspected and found satisfactory against traceable International Standards for its function on the date of inspection. These conform to manufacturer's specification and have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise noted below, conform in all respects to the specifications relevant here to.

**Date of Inspection:** 18-Apr-2024

**Due Date:** 17-Oct-2024

**Additional Certification**

**Sticker Number:** 148272

**Inspected By:**

**Industrial Inspector**



**Approved By:**

**QA/QC Engineer**

P.O. Box No. 2072, Jubail - 31951, K.S.A.  
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881  
Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية  
هاتف ٩٦٦ ١٣ ٣٤٤ ٨٨٨٢ / فاكس ٩٦٦ ١٣ ٣٤٤ ٨٨٨١  
هاتف ٩٦٦ ١٣ ٣٦٧ ٠٥١٥



**Certificate No: UIC/DAM/20242623****Specification:**

|                     |   |           |   |                 |   |          |
|---------------------|---|-----------|---|-----------------|---|----------|
| Rated Power in KVA  | : | 125.0 KVA | - | Speed           | : | 1800 RPM |
| Rated Power Factor  | : | 0.8       | - | Rated Frequency | : | 60 Hz    |
| Rated Voltage       | : | 400 V     | - | Phases          | : | 3Ø       |
| Weight              | : | 2400 kg   | - | Rated Power     | : | 100 kW   |
| Year of Manufacture | : | Sep-23    |   |                 |   |          |

**Inspection and Test:**

|                      |   |              |   |                       |              |
|----------------------|---|--------------|---|-----------------------|--------------|
| Internal Visual Test | : | Satisfactory | - | General Surface Test: | Satisfactory |
| Generator Shut-Down  | : | Satisfactory |   |                       |              |

**Comments & Recommendations:**

The **Generator** was found to be of good working condition and reliable for safe operation.

1. Do not exceed the capacity of the Generator.
2. Inspect the Generator regularly for damage before every use.
3. Check oil level before operation and moisture at outlet of the Generator.
4. Check the condition of the nozzles regularly.
5. Check the condition of Radiator in equal interval.
6. Check the operating characteristic before start the Generator.
7. Unless otherwise specified, all maintenance and service must be carried out the engine Stopped.

**8. Remember - Safety always comes first!**

Inspected By:



Industrial Inspector



Approved By:

  
QA/QC Engineer



الشركة العالمية لخدمات التفتيش المحدودة  
UNIVERSAL INSPECTION CO. LTD.

GENERATOR INSPECTION CHECKLIST

|                |                  |                   |                  |
|----------------|------------------|-------------------|------------------|
| Company:       | Sudhir           | Model Number:     | N/A              |
| Location:      | Abqaiq.          | Manufacture Date: | SEP-2023         |
| Equipment Type | Diesel generator | Serial No.:       | VEPL/2023-24/241 |
| Date:          | 18/APR/2024      | ID No.:           | 551-866-125      |
| Capacity:      | 125 KV           | Sticker No.:      | 148272.          |
| Manufacturer:  | Varada Energies  |                   |                  |

| #    | INSPECTION ITEMS                                  | Pass | Fail | N/A | COMMENT |
|------|---------------------------------------------------|------|------|-----|---------|
| Sr.  | GENERAL                                           |      |      |     |         |
| 1.1  | Last Third-party inspection Certificate / Sticker | ✓    |      |     |         |
| 1.2  | Fire extinguisher in good condition and valid     | ✓    |      |     |         |
| 1.3  | Engine oil level                                  | ✓    |      |     |         |
| 1.4  | Water level                                       | ✓    |      |     |         |
| 1.5  | Fuel level                                        | ✓    |      |     |         |
| 1.6  | Fuel filter water drain                           | ✓    |      |     |         |
| 1.7  | Battery & water                                   | ✓    |      |     |         |
| 1.8  | Leaks in oil system                               | ✓    |      |     |         |
| 1.9  | Leaks in fuel system                              | ✓    |      |     |         |
| 1.10 | Engine minimum and maximum speeds                 | ✓    |      |     |         |
| 1.11 | Lifting eye                                       | ✓    |      |     |         |
| 1.12 | Tires and air pressure                            |      |      |     |         |
| 1.13 | Door hinges                                       |      |      | ✓   |         |
| 1.14 | Shutdown switches                                 | ✓    |      |     |         |
| 1.15 | Handle Lock Pin                                   | ✓    |      |     |         |
| 1.16 | Control panel gauges                              | ✓    |      |     |         |
| 1.17 | Chawlyn valve                                     | ✓    |      |     |         |
| 1.18 | Emergency off Switch                              | ✓    |      |     |         |
| 1.19 | Wheel Stopper                                     |      |      | ✓   |         |
| 1.20 | Earth Cable & Clamp                               | ✓    |      |     |         |

Inspected by: Mohamed Kani

Signature:

User Representative: MOHAMMAD AZAM IMAM

Signature, & Date: 18/4/24