



الشركة العالمية لخدمات التفتيش المحدودة
UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت ٢٠٥٥٠١١٦٤٣



CERTIFICATE OF INSPECTION

Certificate No: UIC/ALH/2024072

Customer : Sudhir Equipment Rental Company
Location : Al Hasa, Kingdom of Saudi Arabia.
Description : Generator
Make : Varada Energies Pvt. Ltd.
Model : N/A
Serial No : VEPL/2023-24/242
Capacity : 125 kVA
ID. No. : SG-867-125

This is to certify that the equipment detailed hereby has been inspected and found satisfactory against traceable International Standards for its function on the date of inspection. These conform to manufacturer's specification and have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise noted below, conform in all respects to the specifications relevant here to.

Date of Inspection: 31-Oct-2023

Due Date: 30-Apr-2024

Additional Certification

Sticker Number: 106576

Inspected By:

34
INSPECTOR
Industrial Inspector



Approved By:

QA/QC Engineer

Certificate No: UIC/ALH/2024072**Specification:**

Set Performance class	:	H	-	Rating Voltage [V]	:	400
Rated power factor	:	0.8	-	Rating KW	:	100
Max.Above Sea-Level [m]	:	1000	-	Mass [kg]	:	2400
Max.Temperature [deg.C]	:	50	-	Rating Frequency [Hz]	:	60

Alternator:

Make	:	Doosan	-	Part No	:	440211-00187C
------	---	--------	---	---------	---	---------------

Reference Standards

:	BS 5000 Part 3 IEC 34-1
:	Nema MG 1-3L ISO 8528-3

Inspection and Test:

Internal Visual Test	:	Satisfactory	-	General Surface Test	:	Satisfactory
Compressor Shut-Down	:	Satisfactory				

Comments & Recommendations:

The **Generator** was found to be of good working condition and reliable for safe operation.

1. Do not exceed the capacity of the Generator.
2. Inspect the Generator regularly for damage before every use.
3. Check the operating characteristic before start the Generator.
4. Unless otherwise specified, all maintenance and service must be carried out the engine Stopped.


5. Remember - Safety always comes first!

Inspected By:


Industrial Inspector



Approved By:


QA/QC Engineer

No. 12302

Client Name & Address of the Site Location:

Mr./Mrs: Gulsh

Purchase Order No : _____

Designation: _____

Date Of Calibration / Inspection : 31-Oct-2023

Tel. No.: _____

Calibration / Inspection Validity : 6m 6M / ~~1Y~~ _____

Fax No.: _____

Location : At Sea

[illegible]

Calibration Engr Sign:  Name: M. Arad

(Client Sign) _____ Name: محمد هادي Contact No: 65981910 Site Location: _____

Witnessed & Approved by 