



الشركة العالمية لخدمات التفتيش المحدودة
UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت ٢٠٥٥٠١١٦٤٣

INSTRUMENT & EQUIPMENT CALIBRATION DIVISION

CERTIFICATE OF CALIBRATION

CERTIFICATE NO: UIC/DAM/74588

This certifies that the instrument below has been tested/calibrated using equipment traceable to National/International Standards or verified by ratio type measurements using self calibrating techniques.

Information on the calibration process and the results are produced below and given in the accompanying sheets of this document.

All related traceable documents are on file at **UNIVERSAL INSPECTION CO. LTD.** and may be examined on request

Customer **Sudhir Equipment Rental Company**
Address Dammam, Kingdom of Saudi Arabia

Description **Pressure Relief Valve**
Manufacturer HARSHAD
Type N/A
Serial No. 2508086
ID No. SAC-250-401
Location Calibration Lab (Dammam)

Receipt Date : 24-Dec-25
Calibration Date : 24-Dec-25
Calibration Due Date : 23-Jun-26

The instrument was calibrated using the following reference, maintained at UIC Instrument & Equipment Calibration division conforming to ISO/IEC 17025:2017 requirements

Reference Standard Equipment Used

Description	Model / Cert. No.	Serial No	Due Date
High Pressure Pneumatic Pressure Source	SA178189-224312	214E2408011	02-Dec-26
Digital Pressure Calibrator	SA178189-224313	2232411017	02-Dec-26

Calibrated By



Calibration Engineer

Approved By



QA/QC Engineer

The measurement results pertain only to the instrument calibrated.

This certificate and the attached measurement result sheets shall not be reproduced except in full without the prior permission

P.O. Box No. 2072, Jubail - 31951, K.S.A.
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881
Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية
هاتف ٨٨٨٢ ١٣ ٩٦٦ / فاكس ٨٨٨١ ١٣ ٩٦٦
هاتف ٠٥١٥ ٣٦٧ ١٣ ٩٦٦

CERTIFICATE NO: UIC/DAM/74588

Page

2 of 2

Customer **Sudhir Equipment Rental Company**

Address Dammam, Kingdom of Saudi Arabia

Description **Pressure Relief Valve**

Manufacturer HARSHAD

Type N/A

Serial No. 2508086

ID No. SAC-250-401

Calibration Date 24-Dec-25

Calibration Due Date 23-Jun-26

Temperature 23.5°C

Relative Humidity RH 46%

Test Results

Set Pressure : 9.50 BAR

Spring Range : N/A

Back Pressure : 0.00 BAR

Size Inlet/outlet: 3/4"

CDTP : 9.50 BAR

Setting Accuracy : $\pm 3\%$ of Setting

Type of Valve : Metal Seated

Pop Test : PASSED

Test Medium : Air

BASIS OF TEST:

Ref Standard ASME Sec VIII, Div I

Summary of Test Procedure:

The Calibration of above Pressure relief valve is performed through the verification of set pressure and seat tightness using a reference standard pressure gauge or test gauge and a hydrostatic / pneumatic test system.

Traceability:

The reported tests were undertaken using equipment detailed mentioned in Reference Standard Equipment's for which the company maintains Traceability to the third party.

Condition of Instrument

With in the tolerance on receipt(as found)

No

The instrument was adjusted

Yes

The instrument was repaired

No

Calibrated By: _____



Calibration Engineer

++++ End of the Certificate +++++



Approved by: _____

QA/QC Engineer

الشركة العالمية لخدمات التفتيش المحدودة
UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س. ت ۲۰۵۵۰۱۱۶۴۳

Sudhir

Delivery Note

مذكرة تسليم

No. : رقم :

Date : 24.12.2025 التاريخ:

[illegible]

Name : Helmi Nur Hafidha

Signature : _____

Mobile No :

Date & Time of Departure : 25/12/23 A.M./P.M.

TOTAL

(Workshop/Stores)

IMPORTANT NOTE:

- 1) The Calibrated/Inspected Instruments/Equipments to be verified by Client immediately after receiving from UIC. If there is any complaints or suspected defects in instruments or any corrections required in Calibration Certificates should be notified to UIC within a day. Based on client request, UIC will consider & do the recalibration and reissue the certificates without any additional cost.
- 2) if failed to notify within a day, it is considered as there is no any defects on calibrated instruments/equipment and not required any changes on the calibration certificates as well as accepted by the client
- 3) The delay in notification to UIC, will be considered as new job and recalibration, charges will be applicable as usual.

P.O. Box No. 2072, Jubail - 31951, K.S.A.

Tel.: +966 13 344 8882 / Fax: +966 13 344 8881 www.ui.com.sa

Tel.: +966 13 367 0515

، الجبيل ٣١٩٥١- المملكة العربية السعودية

+۹۶۶۱۳۳۴ / فاکس +۹۶۶۱۳۳۴

+ 9771337

UIC - QP - 7.