



الشركة العالمية لخدمات التفتيش المحدودة UNIVERSAL INSPECTION CO. LTD.

CR No.2055011643

س.ت ٢٠٥٥٠١١٦٤٣

INSTRUMENT & EQUIPMENT CALIBRATION DIVISION

CERTIFICATE OF CALIBRATION

CERTIFICATE NO: UIC/DAM/40802

This certifies that the instrument below has been tested/calibrated using equipment traceable to National/International Standards or verified by ratio type measurements using self calibrating techniques.

Information on the calibration process and the results are produced below and given in the accompanying sheets of this document.

All related traceable documents are on file at **UNIVERSAL INSPECTION CO. LTD.** and may be examined on request

Customer Sudhir Equipment Rental Company
Location Dammam, Kingdom of Saudi Arabia

Description Pressure Relief Valve
Manufacturer Harshad
Model No. N/A
Serial No. 2401732
ID. No. SAC-500-221
Location Calibration Lab (Dammam)

Receipt Date : 06-Oct-24
Calibration Date : 06-Oct-24
Calibration Due Date : 05-Apr-25

The instrument was calibrated using the following reference, maintained at UIC Instrument & Equipment Calibration division conforming to ISO 17025 requirements

Reference Standard Equipment Used

Description	Model / Cert. No.	Serial No	Due Date
High Pressure Pneumatic Pressure Source	SA 178189-210065	214E191209	23-Apr-25
Digital Pressure Calibrator	SA 178189-210066	23162191108	23-Apr-25

Calibrated By



Calibration Engineer

UIC-OP-7.8-24 F02, REV 0

Approved By

QA/QC Engineer

The measurement results pertain only to the instrument calibrated.

This certificate and the attached measurement result sheets shall not be reproduced except in full without the prior permission

P.O. Box No. 2072, Jubail - 31951, K.S.A.
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881
Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية
هاتف ٩٦٦ ١٣ ٣٤٤ ٨٨٨٢ / فاكس ٩٦٦ ١٣ ٣٤٤ ٨٨٨١
هاتف ٩٦٦ ١٣ ٣٦٧ ٠٥١٥

CERTIFICATE NO: UIC/DAM/40802		Page 2 of 2
Customer Address	Sudhir Equipment Rental Company Dammam, Kingdom of Saudi Arabia	
Description	Pressure Relief Valve	
Manufacturer	Harshad	Calibration Date 06-Oct-24
Model	N/A	Calibration Due Date 05-Apr-25
Serial No.	2401732	Temperature Range 23.5°C
ID. No.	SAC-500-221	Relative Humidity RH 46%
<u>Test Results</u>		
Set Pressure :	16.00 BAR	Spring Range : N/A
Back Pressure :	0.00 BAR	Size Inlet/Outlet : 1" × 1½"
CDTP :	16.00 BAR	
Setting Accuracy :	± 3 % of Setting	Type of Valve : Metal Seated
Pop Test : PASSED		Test Medium : Air
<u>BASIS OF TEST:</u>		
Ref Standard ASME Sec VIII, Div I		
<u>Summary of Test Procedure:</u>		
The Calibration of above Pressure relief valve is performed through the verification of set pressure and seat tightness using a reference standard pressure gauge or test gauge and a hydrostatic / pneumatic test system.		
<u>Traceability:</u>		
The reported tests were undertaken using equipment detailed mentioned in Reference Standard Equipment's for which the company maintains Traceability to the third party.		
<u>Condition of Instrument</u>		
With in the tolerance on receipt(as found)	No	
The instrument was adjusted	Yes	
The instrument was repaired	No	
++++ End of the Certificate +++++		
 Calibrated By: _____ Calibration Engineer	 UIC-QP-7.8-24 F02, REV 0	Approved by:  QA/QC Engineer