



الشركة العالمية لخدمات التفتيش المحدودة UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س. ت ٢٠٥٥٠١١٦٤٣

INSTRUMENT & EQUIPMENT CALIBRATION DIVISION

CERTIFICATE OF CALIBRATION CERTIFICATE NO: UIC/DAM/66132

This certifies that the instrument below has been tested/calibrated using equipment traceable to National/International Standards or verified by ratio type measurements using self calibrating techniques.

Information on the calibration process and the results are produced below and given in the accompanying sheets of this document.

All related traceable documents are on file at **UNIVERSAL INSPECTION CO. LTD.** and may be examined on request

Customer Sudhir Equipment Rental Company
Address Dammam, Kingdom of Saudi Arabia

Description Pressure Relief Valve
Manufacturer HARSHAD
Type N/A
Serial No. 2404904
ID No. SAC-825-233
Location Calibration Lab (Dammam)

Receipt Date : 25-Sep-25
Calibration Date : 27-Sep-25
Calibration Due Date : 26-Mar-26

The instrument was calibrated using the following reference, maintained at UIC Instrument & Equipment Calibration division conforming to ISO 17025 requirements

Reference Standard Equipment Used

Description	Model / Cert. No.	Serial No	Due Date
High Pressure Pneumatic Pressure Source	AME/24/TC/1212-A7	214E2408011	13-Dec-25
Digital Pressure Calibrator	AME/24/TC/1212-A12	2232411017	13-Dec-25

Calibrated By
64
Calibration Engineer



Approved By

QA/QC Engineer


The measurement results pertain only to the instrument calibrated.

This certificate and the attached measurement result sheets shall not be reproduced except in full without the prior permission

P.O. Box No. 2072, Jubail - 31951, K.S.A.
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881
Tel.: +966 13 367 0515

ص. ب ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية
هاتف ٩٦٦ ١٣ ٣٤٤ ٨٨٨٢ / فاكس ٩٦٦ ١٣ ٣٤٤ ٨٨٨١
هاتف ٩٦٦ ١٣ ٣٦٧ ٠٥١٥

www.ui.com.sa

CERTIFICATE NO: UIC/DAM/66132		Page 2 of 2
Customer	Sudhir Equipment Rental Company	
Address	Dammam, Kingdom of Saudi Arabia	
Description	Pressure Relief Valve	
Manufacturer	HARSHAD	Calibration Date 27-Sep-25
Type	N/A	Calibration Due Date 26-Mar-26
Serial No.	2404904	Temperature 23.5°C
ID No.	SAC-825-233	Relative Humidity RH 45%
Test Results		
Set Pressure :	10.00 BAR	Spring Range : N/A
Back Pressure :	0.00 BAR	Size Inlet/outlet : 1" x 2"
CDTP :	10.00 BAR	Type of Valve : Metal Seated
Setting Accuracy :	± 3 % of Setting	Test Medium : Air
Pop Test : PASSED		
BASIS OF TEST:		
Ref Standard ASME Sec VIII, Div I		
Summary of Test Procedure:		
The Calibration of above Pressure relief valve is performed through the verification of set pressure and seat tightness using a reference standard pressure gauge or test gauge and a hydrostatic / pneumatic test system.		
Traceability:		
The reported tests were undertaken using equipment detailed mentioned in Reference Standard Equipment's for which the company maintains Traceability to the third party.		
Condition of Instrument		
With in the tolerance on receipt(as found)	No	
The instrument was adjusted	Yes	
The instrument was repaired	No	
++++ End of the Certificate +++++		
 Calibrated By: _____ Calibration Engineer	 Approved by:  QA/QC Engineer	UIC-QP-7.8-24 F02, REV 0