



الشركة العالمية لخدمات التفتيش المحدودة UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت ٢٠٥٥٠١١٦٤٣

INSTRUMENT & EQUIPMENT CALIBRATION DIVISION

CERTIFICATE OF CALIBRATION

CERTIFICATE NO : UIC/RIY/45388

This certifies that the instrument below has been tested/calibrated using equipment traceable to National/International Standards or verified by ratio type measurements using self calibrating techniques.

Information on the calibration process and the results are produced below and given in the accompanying sheets of this document.

All related traceable documents are on file at **UNIVERSAL INSPECTION CO. LTD.** and may be examined on request

Customer Sudhir Equipment Rental Company.

Address Dammam, Kingdom of Saudi Arabia

Description Pressure Relief Valve

Manufacturer AFS **Receipt Date** : 17-Jun-26

Part No. AK28X-16T **Calibration Date** : 18-Jun-26

Serial No. 250213 **Report Date** : 18-Jun-26

ID No. N/A **Issue date** : 18-Jun-26

Location Calibration Lab **Calibration Due Date** : 17-Dec-26

The instrument was calibrated using the following reference, maintained at UIC Instrument & Equipment Calibration division conforming to ISO 17025 requirements

Reference Standard Equipment Used

Description	Model/Cert No	Serial No	Due Date
Ultra High Pressue Comparator	SA178189-223323	213K2303016	9-Oct-26
Digital Pressure Calibrator	SA178189-223322	2232303033	9-Oct-26

Calibrated By

13
Calibration Engineer



UIC-QP-7.8.2-17, REV 02

Approved By

QA/QC Engineer

The measurement results pertain to the instrument calibrated.

This certificate and the attached measurement result sheets shall not be reproduced except in full without the prior permission

P.O. Box No. 2072, Jubail - 31951, K.S.A.

Tel.: +966 13 344 8882 / Fax: +966 13 344 8881

Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية

هاتف ٨٨٨٢ ١٣ ٣٤٤ / فاكس ٨٨٨١ ١٣ ٣٤٤ +٩٦٦

هاتف ٠٥١٥ ١٣ ٣٦٧ +٩٦٦

CERTIFICATE NO : UIC/RIY/45388

PAGE

1 of 2

Customer	Sudhir Equipment Rental Company.		
Address	Dammam, Kingdom of Saudi Arabia		
Description	Pressure Relief Valve	Calibration Date	18-Jun-26
Manufacturer	AFS	Calibration Due Date	17-Dec-26
Model	AK28X-16T	Temperature	23.0 ± 2°C
Serial No.	250213	Relative Humidity	RH 45% to 75%
ID No.	N/A		

Test Results

Set Pressure :	12.0	BAR	Spring Range	: 16 BAR
Back Pressure:	0.0	BAR	Size Inlet / Outlet	: 1"X 1 1/4"
CDTP :	12.0	BAR	Type of Valve	: Metal Seated
Setting Accuracy :	± 3 % of Setting		Test Medium	: Air/Water/Oil/Gas
Pop Test :	PASSED			

BASIS OF TEST:

Ref Standard ASME Sec VIII, Div I

Summary of Test Procedure:

The Calibration of above Pressure relief valve is performed through the verification of set pressure using a reference standard pressure gauge or test gauge and a hydrostatic / pneumatic test system.

Traceability:

The reported tests were undertaken using equipment detailed mentioned in Reference Standard Equipment's for which the company Maintains traceability to the third party.

Condition of Instrument

With in the tolerance on receipt(as found)	No
The instrument was adjusted	Yes
The instrument was repaired	No

Result:

Calibration Result is pass.



◆◆◆◆◆ End of the Certificate ◆◆◆◆◆



Calibrated By: _____
Calibration Engineer

Approved by:
QA/QC Engineer