



الشركة العالمية لخدمات التفتيش المحدودة
UNIVERSAL INSPECTION CO. LTD.
CR No. 2055011643 س.ت ٢٠٥٥٠١١٦٤٣



CERTIFICATE OF INSPECTION

Certificate No: UIC/DAM/20203561

Customer : Sudhir Equipment Rental Company

Location : Dammam, Kingdom of Saudi Arabia.

Description : WATER PUMP

Make : YORK

Model : YAEP99WD9C50PA

ID No : SCWP30-013

This is to certify that the device detailed hereby has been inspected and found satisfactory against traceable International Standards for its function on the date of inspection. These conform to manufacturer's specification and have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise noted below, conform in all respects to the specifications relevant here to.

Date of Inspection: 12-Nov-2022

Due Date: 11-Nov-2023

Additional Certification

Sticker Number: 73769

Inspected By:


Industrial Inspector



Approved By:


QA/QC Engineer

P.O. Box No. 2072, Jubail - 31951, K.S.A.
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881
Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية
هاتف ٨٨٨٢ ٣٤٤ ١٣ / فاكس ٨٨٨١ ٣٤٤ ١٣ +٩٦٦
هاتف ٥١٥ ٣٦٧ ١٣ +٩٦٦

Certificate No: UIC/DAM/20203561**Specification:**

Power	:	45 Kw	-	Cooling Capacity:	37 KW
Power Supply	:	400 V	-	Phase	: 3
Freequency	:	60 Hz	-	Dimension	: 2000 x 500 mm
Weight	:	800 – 1000 Kg	-	Mfg.Date	: 2013

Inspection and Test:

Internal Visual Test	:	Satisfactory	General Surface Test	:	Satisfactory
Compressor Shut-Down	:	Satisfactory			

Comments & Recommendations:


The Water Pump was found to be of good working condition and reliable for safe operation.

- On the Date of inspection, the equipment found to be of Good Construction, of adequate strength, in good working order and free from apparent defects that affect safe operation.
- On the date of Inspection, we made thorough examination of the equipment specified.
- Check oil level before operation and moisture at outlet of the Water Pump.
- Check the engine and radiators in equal intervals.
- **Remember - Safety always comes first!**

Inspected By:


Industrial Inspector

**Approved By:**


QA/QC Engineer