



الشركة العالمية لخدمات التفتيش المحدودة

UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت. ٢٠٥٥٠١١٦٤٣



## CERTIFICATE OF INSPECTION

Certificate No: UIC/DAM/20203558

**Customer :** Sudhir Equipment Rental Company

**Address :** Dammam, Kingdom of Saudi Arabia.

**Description :** Air-Cooled Chiller

**Make :** YORK

**Model :** YAEP99WD9C50PA

**Serial No :** 50531F31809161

**ID. No. :** SCH200-010

This is to certify that the device detailed hereby has been inspected and found satisfactory against traceable International Standards for its function on the date of inspection. These conform to manufacturer's specification and have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise noted below, conform in all respects to the specifications relevant here to.

**Date of Inspection:** 12-Nov-2022

**Due Date:** 11-Nov-2023

**Additional Certification**

**Sticker Number:** 73766

**Inspected By:**



**Industrial Inspector**



**Approved By:**

*[Signature]*  
**QA/QC Engineer**

P.O. Box No. 2072, Jubail - 31951, K.S.A.  
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881  
Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب. ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية  
هاتف ٨٨٨٢ ١٣ ٣٤٤ / فاكس ٨٨٨١ ١٣ ٣٤٤ +٩٦٦  
هاتف ٠٥١٥ ١٣ ٣٦٧ +٩٦٦

**Certificate No: UIC/DAM/20203558****Specification:**

|                    |   |                  |   |               |   |             |
|--------------------|---|------------------|---|---------------|---|-------------|
| Voltage Range      | : | 440 V            | - | Phase         | : | 3 ph        |
| Frequency          | : | 60 Hz            | - | Cooling Power | : | 213 KW      |
| Cooling capacity   | : | 626 KW           | - | Ref./Charge   | : | R22/47+47Kg |
| Max. working pres. | : | 0.98MPa          | - | Weight        | : | 5079Kg      |
| MFG. Date          | : | 02/26/13         | - | Current       | : | 542 amps    |
| Dimension          | : | 5703X2241X2490mm |   |               |   |             |

**Inspection and Test:**

|                       |   |              |   |                      |   |              |
|-----------------------|---|--------------|---|----------------------|---|--------------|
| Internal Visual Test  | : | Satisfactory | - | General Surface Test | : | Satisfactory |
| Condenser Fans & Coil | : | Satisfactory | - | Evaporator Coil      | : | Satisfactory |
| Control Panel         | : | Satisfactory |   |                      |   |              |

**Comments & Recommendations:**

The Air Cooled Chiller was found to be of good working condition and reliable for safe operation.

1. Do not exceed the capacity of the Air Cooled Chiller.
2. Check oil level before operation and moisture at outlet of the Air Cooled Chiller.
3. Check the condition of Radiator, Condenser, and Coil in equal interval.
4. Check the operating characteristic before start the Air Cooled Chiller.
5. Unless otherwise specified, all maintenance and service must be carried out the engine Stopped.
6. **Remember - Safety always comes first!**

**Inspected By:****Industrial Inspector****Approved By:**

*[Signature]*  
QA/QC Engineer