



الشركة العالمية لخدمات التفتيش المحدودة UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت ٢٠٥٥٠١١٦٤٣

INSTRUMENT & EQUIPMENT CALIBRATION DIVISION

CERTIFICATE OF CALIBRATION

CERTIFICATE NO: UIC/DAM/11113

This certifies that the instrument below has been tested/calibrated using equipment traceable to National/International Standards or verified by ratio type measurements using self calibrating techniques.

Information on the calibration process and the results are produced below and given in the accompanying sheets of this document.

All related traceable documents are on file at **UNIVERSAL INSPECTION CO. LTD.** and may be examined on request

Customer **Sudhir Equipment Rental Company**
Address Dammam, Kingdom of Saudi Arabia

Description **Pressure Relief Valve**
Manufacturer N/A
Model N/A
Serial No. N/A
ID No. SCH200-015-2
Location Calibration Lab(Dammam)

Receipt Date : 12-Nov-22
Calibration Date : 12-Nov-22
Calibration Due Date : 11-Nov-23

The instrument was calibrated using the following reference, maintained at UIC Instrument & Equipment Calibration division conforming to ISO 17025 requirements

Reference Standard Equipment Used

Description	Model / Cert. No.	Serial No	Due Date
High Pressure Pneumatic Pressure Source	DSC-21-01475	214E191209	20-Mar-23
Digital Pressure Calibrator	DSC-21-01474	223162191108	20-Mar-23

Calibrated By

Calibration Engineer



UIC-QP-7.8-24 F02, REV 0

Approved By

QA/QC Engineer


The measurement results pertain only to the instrument calibrated.

This certificate and the attached measurement result sheets shall not be reproduced except in full without the prior permission

P.O. Box No. 2072, Jubail - 31951, K.S.A.
Tel.: +966 13 344 8882 / Fax: +966 13 344 8881
Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية
هاتف ٨٨٨٢ ١٣ ٣٤٤ / فاكس ٨٨٨١ ١٣ ٣٤٤ +٩٦٦
هاتف ٠٥١٥ ٣٦٧ ١٣ ٩٦٦ +٩٦٦

CERTIFICATE NO:		UIC/DAM/11113		Page	2 of 2
Customer Address	Sudhir Equipment Rental Company Dammam, Kingdom of Saudi Arabia				
Description	Pressure Relief Valve	Calibration Date	12-Nov-22		
Manufacturer	N/A	Calibration Due Date	11-Nov-23		
Model	N/A	Temperature	23.2°C		
Serial No.	N/A	Relative Humidity	RH 52%		
ID No.	SCH200-015-2				
Test Results					
Set Pressure	: 65.00	Psi	Spring Range : N/A		
Back Pressure	: 0.00	Psi	Size Inlet : 1/4"		
CDTP	: 65.00	Psi	Type of Valve : Metal Seated		
Setting Accuracy	: ± 3 % of Setting		Test Medium : Air/Water/Oil/Gas		
Pop Test : PASSED					
BASIS OF TEST:					
Ref Standard ASME Sec VIII, Div I					
Summary of Test Procedure:					
The Calibration of above Pressure relief valve is performed through the verification of set pressure and seat tightness using a reference standard pressure gauge or test gauge and a hydrostatic / pneumatic test system.					
Traceability:					
The reported tests were undertaken using equipment detailed mentioned in Reference Standard Equipment's for which the company maintains Traceability to the third party.					
Condition of Instrument					
With in the tolerance on receipt(as found)			No		
The instrument was adjusted			Yes		
The instrument was repaired			No		
***** End of the Certificate *****					
Calibrated By:			Approved by: 		
Calibration Engineer		QA/QC		QA/QC Engineer	