

THIRD PARTY INSPECTION CERTIFICATE
GENERATOR

Certificate No : HIT-CRT-22-1226

Job No JO-INS-22-644

Sticker No	1218
Result	Pass

Timesheet	CL-1178
Checklist	CL-1178

Client Name & Address	Inspection Date	23-Apr-2022
Sudhir Equipment Rental Company	Expiration Date	22-Apr-2023
Sharma	Validity	12 Month's
Kingdom of Saudi Arabia	Types of Inspection	
Equipment Location	Sharma	Periodic Visual & Functional

Equipment Description	Load Test Chart			
Diesel Driven Generator	Boom ↔	Radius →	Test Load	S.W.L.
	(Meter)	(Meter)	(Tonne)	(Tonne)
	NA	NA	NA	NA

Load Limit (S.W.L.)	500 KVA	Manufacturer	VARADA ENERGIES
Serial No.	VEPL/2018/19/0034	Date of Mfg.	NA
Model	VEPL	Owner ID/Plat No	SG-363-500
Frequency	60 Hz	Max Platform Height	NA
Voltage	400 V	Max Length	NA
Power Factor	0.8	Max Width	NA
Max Site Temp	50°	Gross Weight	7050 kg
Wheel Type	NA	Person Allowed	1

Previous Inspection Details	Next Inspection Date	Reference Standard
NA	23-Apr-23	IEC 88528-11

Recommendation

Found satisfactory at the time of Inspection.

Authorized By: ASHADULLAH KHAN

Inspected By: ISRAN SHAREEF



No liabilities will be considered against Haykalah Inspection Est. for failure, damage or other occurrence to client owned or operated equipment due to misuse, improper installations, poor maintenance, weather/environmental conditions & equipment operator/user mistakes or uncontrolled operation & maintenance. The concerned inspector or representative has thoroughly examined the equipment in accordance to the relevant standards. Inspection indicates that the mentioned equipment/tools/machine has no apparent defects which may prove dangerous during normal operation and it's found satisfactory for further use with provided their regular maintenance and operated by a certified operator. This certificate/report shall not be generated without an official approval in between Haykalah Inspection Est. and Client. Certificate becomes invalid if any modification/repair is made to the equipment.