



الشركة العالمية لخدمات التفتيش المحدودة

UNIVERSAL INSPECTION CO. LTD.

CR No. 2055011643

س.ت. ٢٠٥٥٠١١٦٤٣



CERTIFIED
ISO 9001 : 2015

CERTIFICATE OF INSPECTION

Certificate No: UIC/RIY/20220627

Customer : Sudhir Equipment Rental Company

Address : Dammam, Kingdom of Saudi Arabia

Description : Generator

Make : CUMMINS

Model Number : P1250C

Serial No : K18PI503569

ID. No. : SG-365-250

This is to certify that the Equipment detailed hereby have been tested against traceable International Standards for Visual & Functional Test on the date of inspection. These conform to manufacturer's specification and have been inspected and tested in accordance with the conditions and requirements of the contract or purchase order and unless otherwise noted below, conform in all respects to the specifications relevant here to.

Date of Testing : 29-JUN-2022

Due Date : 28-DEC-2022

Additional Certification

Sticker Number: 60746

Inspected By:



Industrial Inspector



Approved By:

QA/QC Engineer

P.O. Box No. 2072, Jubail - 31951, K.S.A.

Tel.: +966 13 344 8882 / Fax: +966 13 344 8881

Tel.: +966 13 367 0515

www.ui.com.sa

ص.ب. ٢٠٧٢، الجبيل ٣١٩٥١ - المملكة العربية السعودية

هاتف ٨٨٨٢ ١٣ ٩٦٦ / فاكس ٨٨٨١ ١٣ ٩٦٦

هاتف ٠٥١٥ ٣٦٧ ٩٦٦

Certificate No: UIC/RIY/20220627**Specification:**

Capacity Kva	:	225 KVA	-	Capacity KW	:	200 Kw
Speed	:	1800 Rpm	-	INS Class	:	H
Rated Power Factor:		0.8	-	Rated Frequency	:	60 Hz
Set Performance	:	H	-	Rated Voltage	:	380 Volts
Phase	:	3	-	Rated Current	:	854 Amps
Weight	:	6000Kg				

Engine Specification:

Engine Make	:	Cummins	-	Engine Model	:	P1250C
Engine Serial No	:	84496043	-	Alter Serial No	:	N18G270896

Inspection and Test:

Internal Visual Test	:	Satisfactory	General Surface Test	:	Satisfactory
Compressor Shut-Down	:	Satisfactory			

Comments & Recommendations:

The Generator was found to be of good working condition and reliable for safe operation.

1. Do not exceed the capacity of the Generator.
2. Inspect the Generator regularly for damage before every use.
3. Check oil level before operation and moisture at outlet of the Generator.
4. Check the condition of the nozzles regularly.
5. Check the condition of Radiator in equal interval.
6. Unless otherwise specified, all maintenance and service must be carried out the engine Stopped.
7. **Remember - Safety always comes first!**

Inspected By:

Industrial Inspector



Approved By:

QA/QC Engineer